

EnergyAustralia Yallourn Pty Ltd Monthly Air Emissions Compliance Report September 2023

Monthly Discharge to Air Compliance Executive Summary					
Indicator	Carbon Monoxide	Oxides of Nitrogen (as NO ₂)	Particles (Total)	Sulphur Dioxide	
Maximum Licence Limit (g/min)	139,000	51,600	24,100	104,000	
Monthly Maximum Reported (g/min)	59,565	21,664	14,331	75,832	
90th Percentile Licence Limit (g/min)	85,600	49,100	14,500	73,100	
YTD Month End 90th Percentile (g/min)	30,295	22,594	12,304	47,920	
Discharge to Air Licence Limit Compliance	100%	100%	100%	100%	
Monitoring System Availability (%)	100%	100%	100%	100%	

EPA Licence Site Details				
Licence Holder	EnergyAustralia Yallourn PTY LTD			
Licence Number	10961			
Premises Address	Eastern Rd, Yallourn VIC 3825			
Site Description	This licence applies to a premises, where brown coal is mined and electricity is generated in a brown coal fired power station.			
Reporting Period	September 2023			
	A1: Latitude -38.1769981; Longitude 146.345441			
Licence Discharge Points	A2a: Latitude -38.1769981; Longitude 146.3454416			
	A2b: Latitude -38.1772303; Longitude 146.3447922			
	Annual Performance Statement			
	Current EPA Licence			
Websites	EPA AirWatch			
	Latrobe Valley Air Monitoring Network Inc.			

Discharge to Air Licence Limits						
Discharge Point	Description of Discharge Point	Indicator	Units[1]	90th Percentile Limit[2]	Maximum Limit	Frequency[3]
		Carbon Monoxide	g/min	85,600	139,000	Continuous
A1, A2a, A2b	I for AT AZA I	Oxides of Nitrogen (as NO ₂)	g/min	49,100	51,600	Continuous
		Particles (Total)	g/min	14,500	24,100	Continuous
		Sulfur Dioxide	g/min	73,100	104,000	Continuous

- [1] g/min =grams per minute 30 minute average[2] 90th percentile limits are based on a 12-month rolling average[3] Monitoring Frequency

Monthly Air Emissions Daily Performance					
Indicator	Carbon Monoxide Daily Maximum (g/min)	Oxides of Nitrogen (as NO ₂) Daily Maximum (g/min)	Particles (Total)[5] Daily Maximum (g/min)	Sulfur Dioxide Daily Maximum (g/min)	
Maximum Limits	139,000	51,600	24,100	104,000	
01-Sep-23	22,453	13,608	8,444	27,935	
02-Sep-23	59,565	15,817	14,331	58,602	
03-Sep-23	33,529	16,096	14,151	61,264	
04-Sep-23	20,811	17,175	12,520	40,968	
05-Sep-23	22,652	16,423	12,981	41,860	
06-Sep-23	19,646	21,664	12,701	46,104	
07-Sep-23	13,043	13,994	7,987	25,298	
08-Sep-23	29,120	17,612	10,618	32,756	
09-Sep-23	27,156	16,577	10,622	33,503	
10-Sep-23	31,758	17,248	12,285	35,695	
11-Sep-23	30,611	17,280	11,640	34,782	
12-Sep-23	26,626	17,271	10,795	37,549	
13-Sep-23	33,795	18,343	13,027	44,330	
14-Sep-23	18,630	16,955	12,120	42,565	
15-Sep-23	17,569	9,402	12,201	38,535	
16-Sep-23	15,477	10,227	6,685	36,645	
17-Sep-23	28,836	10,774	6,758	39,116	
18-Sep-23	21,222	10,365	8,029	31,995	
19-Sep-23	16,592	10,335	7,195	24,292	
20-Sep-23	29,589	11,429	8,897	25,046	
21-Sep-23	20,949	11,716	11,574	30,339	
22-Sep-23	28,915	11,263	10,734	37,407	
23-Sep-23	18,129	10,263	10,543	26,244	
24-Sep-23	13,532	9,562	10,333	24,060	
25-Sep-23	14,538	9,326	9,966	39,540	
26-Sep-23	23,952	10,247	11,409	59,434	
27-Sep-23	14,043	11,285	12,446	75,832	
28-Sep-23	12,041	11,277	11,511	66,158	
29-Sep-23	15,943	10,839	9,290	63,189	
30-Sep-23	11,315	9,838	8,587	57,814	

	Air Emissions 90th Percentile Performance [2]					
	Carbon Monoxide (g/min)	Oxides of Nitrogen (as NO ₂) (g/min)	Particles (Total)[5] (g/min)	Sulfur Dioxide(g/min)		
90th Percentile Licence Limits	85,600	49,100	14,500	73,100		
90th Percentile (Month End)	30,295	22,594	12,304	47,920		

^[5] In accordance with licence condition LI_DA1.10.3 & and LI_DA1.10.4 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

Monthly Data Explanation

Licence Limit Exceedances

	This table provides a summary and explanation of exceedances of air discharge limits			
Date	Indicator Exceeded Location (A1, A2a, A2b)		Explanation	
N/A	N/A	N/A	N/A No exceedances of licence conditions were reported for the month of Septem	

Monitoring Systems Availability

This table provides a summary of missing data periods requiring substitutions used for determination of daily compliance status				
Date/Time Loss of Availability (% of month) Indicator (A1, A2a, A2b)				Explanation
N/A	N/A	N/A	N/A	No data losses were reported for the month of September

Yallourn Power Station - Licenced Discharge to Air Points

