B Monitoring and Complaints Summary

Period: 1/06/2023 to 1/07/2023

B1 Number of Pollution Complaints 0

S
Energy Australia

26 July 2023

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

 EPL Number:
 555

 Licensee's name:
 ENERGYAUSTRALIA TALLAWARRA

 Licensee's address:
 Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

 Link to EPL:
 <a href="http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&opt_ion=licence&searchrange=licence&range=POEO%20licence&prp=no&status=I

 ssued
 <a href="http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&opt_ion=licence&searchrange=licence&range=POEO%20licence&prp=no&status=I

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	18/05/2023	7	7	7	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	18/05/2023	28	28	28	30

Comments:

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit	
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.4	13.9	16.6	NA*	Energy Australia
Notes:	*Tallawarra do receiving wate		ater quality licence	limits for ambient	: water qualit	y monitoring	in its EPL. AN	IZECC Guidel	ines apply to

Monitoring Point 4: Ambient water monitoring

Periods where the plant is offline or Thermoshock is active have been removed from this data set. Comments:

26 July 2023

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
Pollutant	Unit of Measure		No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	9.4	13.3	18.1	35

Periods where the plant is offline have been removed from this data set. Comments:

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.0	14.0	18.6	NA*

Comments: n/a

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.3	14.0	16.9	NA*

Comments: n/a



26 July 2023

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
		Monthly	Concetted		- Tulue	sample	Value	
	micrograms	during	0	-	-	_	-	NA*
Copper	per litre	discharge	C C					
		Monthly						
Nitrogen	milligrams per	during	0	-	-	-	-	NA*
(total)	litre	discharge						
		Monthly						
		during	0	-	-	-	-	NA*
рН	рН	discharge						
Total								
Phosporous -		Monthly						 *
filtered	milligrams per	during	0	-	-	-	-	NA*
sample	litre	discharge						
Total		Monthly						
suspended	milligrams per	during	0	-	-	-	-	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Zinc	per litre	discharge						



26 July 2023

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitor	ing
---	-----

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.5	4.0	4.3	NA
Moisture content	Percent	Continuous	**	NA	7.1	7.9	8.6	NA
Nitrogen oxides	parts per million	Continuous	**	NA	6.3	9.8	21.3	25
Oxygen (O2)	Percent	Continuous	**	NA	13.0	13.4	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	6/12/2022	-	<0.6	-	10
Sulphur dioxide	parts per million	Yearly	1	6/12/2022	-	1.9	-	3
Temperature	Degrees Celsius	Continuous	**	NA	71.4	83.2	96.4	NA
Volatile organic compounds	parts per million	Yearly	1	6/12/2022	-	<1	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	244.1	351.5	447.6	NA



Notes: * equipment detection limit

Comments:

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

		No. of						
	Unit of	Samples	No. of samples	Date Samples	Lowest	Mean	Highest	Licence
Pollutant	Measure	required	collected	collected	result	result	result	Limit
	Kilolitres per	Continuous	**	NIA	0	10	70	100
Sewage	day	Continuous		NA	0	18	70	100

Notes: ** Continuous data recorded via inline flow meter

Comments:



26 July 2023