B Monitoring and Complaints Summary

Period: 1/04/2016 to 1/05/2016



23 May 2016

B1 Number of Pollution Complaints

0

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	4/year	0	-	1	-	1	20
Total suspended solids	milligrams per litre	4/year	0	-	-	-	-	30

Comments: No effluent irrigated this month

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.0	21.3	34.8	NA*



23 May 2016

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: A high sample value may be recorded at this monitoring point, due to it's location

anditions

within the plant Thermoshock system. These high sample values are not representitive of ambient conditions

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
Pollutant			No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.4	22.0	27.7	35

Comments:

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	18.9	21.9	26.0	NA*



23 May 2016

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Continuous	Cantinuous	NIA	10.5	24 5	24.0	N1 A *
Temperature	Celsius	Continuous	Continuous	NA	19.5	21.5	24.0	NA*

Comments: n/a

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required Monthly	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	discharge	0	-	ı	-	-	NA*
рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per litre	discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



23 May 2016

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No water discharged this month.

Discharge and Monitoring Point 9: Air emissions monitoring

Dallutant	Unit of	No. of Samples	No. of samples	Date samples	Lowest	Mean of	Highest sample	Licence
Pollutant Carbon	Measure	required	collected	collected	value	sample	value	Limit
dioxide	%	Continuous	**	NA	3.8	4.0	4.7	NA
Moisture content	Percent	Continuous	**	NA	9.5	9.8	10.6	NA
Nitric oxide	parts per million	Continuous	**	NA	0.0	0.4	6.2	NA
Nitrogen dioxide	parts per million	Continuous	**	NA	0.0	0.2	1.2	NA
Nitrogen oxides	parts per million	Continuous	**	NA	0.0	0.5	7.4	25
Oxygen (O2)	Percent	Continuous	**	NA	12.7	13.7	14.0	NA
Solid particles	milligrams per cubic metre	Yearly	1	27/11/2015	<0.13	<0.13	<0.13	10
Sulphur dioxide	parts per million	Yearly	1	27/11/2015	<1.4	<1.4	<1.4	3
Temperature	Degrees Celsius	Continuous	**	NA	76.6	82.9	98.4	NA
Volatile organic compounds	parts per million	Yearly	1	27/11/2015	<0.0088	<0.0088	<0.0088	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	253.2	300.4	445.1	NA



Notes: * equipment detection limit

Comments: Some negative NO and NO2 values were recorded during the month. These values have been recorded as zeroes.

* Some missing intermittant data due to communication rpoblems for the month. Data Capture rates remained acceptable.

Monitoring Point 10: Ambient air monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Nitric oxide	parts per hundred million	Continuous	**	NA	-0.1	0.0	1.9	NA
Nitrogen dioxide	parts per hundred million	Continuous	**	NA	0.0	0.3	3.5	NA
Nitrogen oxides	parts per hundred million	Continuous	**	NA	0.0	0.3	4.6	NA
Ozone	parts per hundred million	Continuous	**	NA	0.0	1.5	6.6	NA



23 May 2016

Comments:

*Automatic overnight span/zero checks for Oxides of Nitrogen performed every night between 01:00 - 01:50

*Automatic overnight span/zero checks for Ozone performed and stabilisation every night between 02:00 - 02:40 Due to instrumentation faults, several maintenance periods occurred during the month, resulting in a capture rate of 88.2% for NO, NO2 and NOx. Ozone capture rates were 96.2%

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure		No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes: ** Continuous data recorded via inline flow meter

Comments: No sewage pumped this month