B Monitoring and Complaints Summary

Period: 1/08/2021 to 1/09/2021



B1 Number of Pollution Complaints 0

7 September 2021

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	28/06/2021	5	5	5	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	28/06/2021	25	25	25	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.4	14.2	17.0	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

7 September 2021

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
Pollutant			No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.9	15.3	19.9	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	· •	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.5	14.0	17.8	NA*



7 September 2021

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
	Unit of		No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	C	Cantina	NIA	44.0	442	47.2	N1 A *
Temperature	Celsius	Continuous	Continuous	NA	11.8	14.3	17.3	NA*

Comments: n/a

Comments: n/a

Monitoring Point 8: Discharge water monitoring

	T	No. of	I	Γ	Lowest	I	Highest	1
	linia of		No of sometics	Data samulas		Mannaf	_	Licomos
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Copper	per litre	discharge						
		Monthly						
Nitrogen	milligrams per	during	0	-	-	-	-	NA*
(total)	litre	discharge						
		Monthly						
		during	0	-	-	-	-	NA*
рН	рН	discharge						
Total								
Phosporous -		Monthly						
filtered	milligrams per	during	0	-	-	-	-	NA*
sample	litre	discharge						
Total		Monthly						
suspended	milligrams per	during	0	-	_	-	-	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Zinc	per litre	discharge						



7 September 2021

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.7	4.2	4.4	NA
Moisture content	Percent	Continuous	**	NA	7.3	8.4	8.8	NA
Nitrogen oxides	parts per million	Continuous	**	NA	4.0	11.6	18.5	25
Oxygen (O2)	Percent	Continuous	**	NA	13.0	13.2	14.0	NA
Solid particles	milligrams per cubic metre	Yearly	1	24/07/2020	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	24/07/2020	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	71.7	85.3	93.3	NA
Volatile organic compounds	parts per million	Yearly	1	24/07/2020	-	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	246.5	378.7	435.4	NA



Notes: * equipment detection limit

Comments: n/a



7 September 2021

B3 Volume or Mass Monitoring Summary

day

Monitoring Point 3: Sewage volume monitoring

No. of Unit of Samples No. of samples **Date Samples** Lowest Mean Highest Licence Pollutant Measure required collected collected result Limit result result Kilolitres per ** Continuous NA 0 4 20 100

Notes:

Sewage

** Continuous data recorded via inline flow meter

Comments: