B Monitoring and Complaints Summary

Period: 1/02/2022 to 1/03/2022



B1 Number of Pollution Complaints

1 March 2022

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	15/12/2021	4	4	4	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	15/12/2021	25	25	25	30

0

Comments:

Monitoring Point 4: Ambient water monitoring

P	Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Т	Геmperature	Degrees Celsius	Continuous	Continuous	NA	20.6	24.4	29.1	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

1 March 2022

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Caratian	Cantinuana	NI A	20.0	25.0	20.7	2.5
Temperature	Celsius	Continuous	Continuous	NA	20.8	25.8	30.7	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	20.7	25.0	32.2	NA*



Comments: n/a 1 March 2022

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
Pollutant		•	No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	20.6	24.2	29.1	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

	T	No. of	1		Lowest	1	Highest	1
	linit of		No of complete	Data samulas		Mannaf		Licomos
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Copper	per litre	discharge						
		Monthly						
Nitrogen	milligrams per	during	0	-	-	-	-	NA*
(total)	litre	discharge						
		Monthly						
		during	0	-	-	-	-	NA*
pН	рН	discharge						
Total								
Phosporous -		Monthly	_					
filtered	milligrams per	during	0	-	-	-	-	NA*
sample	litre	discharge						
Total		Monthly						
suspended	milligrams per	during	0	-	_	-	-	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Zinc	per litre	discharge						



1 March 2022

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitoring

	1	No. of		1	Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
Carbon	%	Continuous	**	NA	3.4	4.0	4.2	NA
dioxide	70	Continuous		IVA	5.4	4.0	4.2	INA
Moisture content	Percent	Continuous	**	NA	6.9	7.9	8.4	NA
Nitrogen oxides	parts per million	Continuous	**	NA	3.4	12.6	22.9	25
Oxygen (O2)	Percent	Continuous	**	NA	13.0	13.2	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	9/11/2021	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	9/11/2021	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	78.4	92.9	97.7	NA
Volatile organic compounds	parts per million	Yearly	1	9/11/2021	1	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	248.9	376.6	425.8	NA



Notes:

* equipment detection limit

Comments:



1 March 2022

Volume or Mass Monitoring Summary

B3 Monitoring Point 3: Sewage volume monitoring

No. of Unit of No. of samples **Date Samples** Samples Highest Licence Lowest Mean collected result Pollutant Measure required collected result result Limit Kilolitres per ** 22 100 Continuous 0 3 NA Sewage day

Notes:

** Continuous data recorded via inline flow meter

Comments: