B Monitoring and Complaints Summary

Period: 1/07/2015 to 1/08/2015



26 August 2015

B1 Number of Pollution Complaints

0

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	4/year	0	-	1	1	1	20
Total suspended solids	milligrams per litre	4/year	0	-	-	-	-	30

Comments: No effluent discharged this month.

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	**	NA	10.0	12.1	41.0	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: **Temperature monitored continuously via online probe.

26 August 2015

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Cambinusus	**	NIA	10.2	1.4.4	22.2	25
Temperature	Celsius	Continuous		NA	10.3	14.4	22.2	35

Comments: **Temperature monitored continuously via online probe.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	**	NA	9.5	13.0	16.9	NA*



**Temperature monitored continuously via buoy.

26 August 2015

Monitoring Point 7: Ambient water monitoring

Comments:

		No. of			Lowest		Highest	
Pollutant		•	No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	**	NA	10.6	12.4	15.3	NA*

Comments: **Temperature monitored continuously via buoy.

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	ı	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
рН рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per	discharge	0	-	-	-	-	NA*
Total suspended mi	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



26 August 2015

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month

Discharge and Monitoring Point 9: Air emissions monitoring

	1	No. of			Lowest	ı	Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
Carbon dioxide	%	Continuous	**	NA	1.7	3.3	3.4	NA
Moisture content	Percent	Continuous	**	NA	8.7	10.0	11.3	NA
Nitric oxide	parts per million	Continuous	**	NA	0.0	3.4	10.3	NA
Nitrogen dioxide	parts per million	Continuous	**	NA	0.0	0.4	2.7	NA
Nitrogen oxides	parts per million	Continuous	**	NA	0.0	4.0	11.1	25
Oxygen (O2)	Percent	Continuous	**	NA	12.3	13.4	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	13/03/2015	<0.14	<0.14	<0.14	10
Sulphur dioxide	parts per million	Yearly	1	13/03/2015	<1.5	<1.5	<1.5	3
Temperature	Degrees Celsius	Continuous	**	NA	68.2	79.4	90.1	NA
Volatile organic compounds	parts per million	Yearly	1	13/03/2015	<1.5	<1.5	<1.5	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	236.5	341.4	429.9	NA



Notes: * equipment detection limit

** Continuous data reported based on hourly average CEMS data

Comments: Some negative NO and NO2 values were recorded during the month. These values have been recorded as zeroes.

Component failure resulted in the CEMS instrument being offline from $04/07/15\ 05:40\ to\ 08/07/15\ 15:20$

Monitoring Point 10: Ambient air monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Nitric oxide	parts per hundred million	Continuous	**	NA	0.0	0.1	5.8	NA
Nitrogen dioxide	parts per hundred million	Continuous	**	NA	0.0	0.3	2.3	NA
Nitrogen oxides	parts per hundred million	Continuous	**	NA	0.0	0.3	8.1	NA
Ozone	parts per hundred million	Continuous	**	NA	0.0	1.7	3.1	NA



26 August 2015

Comments:

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure		No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes: ** Continuous data recorded via inline flow meter
Comments: No effluent irrigation occured this month

^{*}Automatic overnight span/zero checks for Oxides of Nitrogen performed every night between 01:00 - 01:50

^{*}Automatic overnight span/zero checks for Ozone performed and stabilisation every night between 02:00 - 02:40

^{*}Scheduled Maintenance 24/07/2015 10:45 to 12:55