B Monitoring and Complaints Summary

Period: 1/06/2017 to 1/07/2017



18 July 2017

B1 Number of Pollution Complaints

Pollution CategoryNumber of ComplaintsAir0Water0Noise0Waste0Other0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	-	1	1	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	1	-	30

0

Comments: No effluent irrigated this month.

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.1	13.7	15.8	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

18 July 2017

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
Pollutant			No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.2	15.0	19.8	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.0	14.2	17.4	NA*



18 July 2017

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.7	14.3	16.1	NA*

Comments: n/a

Comments: n/a

Monitoring Point 8: Discharge water monitoring

	T	No. of	1	Γ	Lowest	I	Highest	1
	linit of		No of complete	Data samulas		Mean of		Licomos
	Unit of	Samples	No. of samples	Date samples	sample		sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Copper	per litre	discharge						
		Monthly						
Nitrogen	milligrams per	during	0	-	-	-	-	NA*
(total) litre	litre	discharge						
		Monthly						
		during	0	-	-	-	-	NA*
рН	рН	discharge						
Total								
Phosporous -		Monthly	_					
filtered	milligrams per	during	0	-	-	-	-	NA*
sample	litre	discharge						
Total	1	Monthly						
suspended	milligrams per	during	0	-	_	-	-	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Zinc	per litre	discharge						



18 July 2017

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.9	4.4	4.9	NA
Moisture content	Percent	Continuous	**	NA	9.5	10.2	10.8	NA
Nitric oxide	parts per million	Continuous	**	NA	0.0	5.6	17.3	NA
Nitrogen dioxide	parts per million	Continuous	**	NA	0.0	0.9	3.2	NA
Nitrogen oxides	parts per million	Continuous	**	NA	0.0	6.4	20.1	25
Oxygen (O2)	Percent	Continuous	**	NA	12.5	13.2	14.0	NA
Solid particles	milligrams per cubic metre	Yearly	1	13/12/2016	<1	<1	<1	10
Sulphur dioxide	parts per million	Yearly	1	13/12/2016	<2	<2	<2	3
Temperature	Degrees Celsius	Continuous	**	NA	75.4	84.5	94.2	NA
Volatile organic compounds	parts per million	Yearly	1	13/12/2016	0.17	0.17	0.17	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	244.9	336.2	445.0	NA



Notes: * equipment detection limit

Comments: Some negative NO and NO2 values were recorded during the month. These values have been recorded as zeroes.

Monitoring Point 10: Ambient air monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Nitric oxide	parts per hundred million	Continuous	**	NA	0.0	0.1	2.5	NA
Nitrogen dioxide	parts per hundred million	Continuous	**	NA	0.1	0.3	1.8	NA
Nitrogen oxides	parts per hundred million	Continuous	**	NA	0.1	0.4	4.4	NA
Ozone	parts per hundred million	Continuous	**	NA	0.1	1.8	3.6	NA



18 July 2017

Comments:

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure		No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes:

** Continuous data recorded via inline flow meter

Comments: