# **B** Monitoring and Complaints Summary

Period: 1/03/2021 to 1/04/2021



16 April 2021

#### B1 Number of Pollution Complaints

Pollution CategoryNumber of ComplaintsAir0Water0Noise0Waste0Other0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

#### **B2** Concentration Monitoring Summary

#### Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	24/03/2021	2	2	2	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	24/03/2021	27	27	27	30

0

#### **Monitoring Point 4: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.7	21.3	25.8	NA*



Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

16 April 2021

#### Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
Pollutant	Unit of Measure		No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	19.1	22.2	29.9	35

Comments: Periods where the plant is offline have been removed from this data set.

### **Monitoring Point 6: Ambient water monitoring**

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	18.4	22.1	27.5	NA*



16 April 2021

Comments: n/a

### **Monitoring Point 7: Ambient water monitoring**

		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	G 1:	6 1:	21.0	40.5	22.2	26.6	81 A ¥
Temperature	Celsius	Continuous	Continuous	NA	19.5	22.3	26.6	NA*

Comments: n/a

#### **Monitoring Point 8: Discharge water monitoring**

	1	IN of	1		Laurant	1	11:-64	1
		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
		Monthly						
	micrograms	during	0	25/03/2021	0.002	0.002	0.002	NA*
Copper	per litre	discharge						
		Monthly						
Nitrogen	milligrams per	during	0	25/03/2021	1.6	1.6	1.6	NA*
(total)	litre	discharge						
		Monthly						
		during	0	25/03/2021	7.3	7.3	7.3	NA*
рН	рН	discharge						
Total								
Phosporous -		Monthly		/ /				
filtered	milligrams per	during	0	25/03/2021	0.44	0.44	0.44	NA*
sample	litre	discharge						
Total		Monthly						
suspended	milligrams per	during	0	25/03/2021	14.0	14.0	14.0	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	0	25/03/2021	<0.005	<0.005	<0.005	NA*
Zinc	per litre	discharge						



16 April 2021

Notes:

\*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

# Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.9	4.1	4.4	NA
Moisture content	Percent	Continuous	**	NA	7.8	8.1	8.8	NA
Nitrogen oxides	parts per million	Continuous	**	NA	4.7	5.5	7.0	25
Oxygen (O2)	Percent	Continuous	**	NA	13.2	13.7	14.0	NA
Solid particles	milligrams per cubic metre	Yearly	1	24/07/2020	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	24/07/2020	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	77.7	81.0	86.0	NA
Volatile organic compounds	parts per million	Yearly	1	24/07/2020	-	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	267.7	288.2	332.9	NA



Notes:

\* equipment detection limit



## **B3** Volume or Mass Monitoring Summary

### Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of		No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	3	23	100

Notes:

\*\* Continuous data recorded via inline flow meter