B Monitoring and Complaints Summary

Period: 1/03/2022 to 1/04/2022

B1 Number of Pollution Complaints 1

C
Energy Australia

14 April 2022

Pollution Category	Number of Complaints
Air	1
Water	0
Noise	0
Waste	0
Other	0

 EPL Number:
 555

 Licensee's name:
 ENERGYAUSTRALIA TALLAWARRA

 Licensee's address:
 Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

 Link to EPL:
 http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&oooption=licence&searchrange=licence&range=POEO%20licence&prp=no&status=lissued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	22/03/2022	4	4	4	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	22/03/2022	22	22	22	30



Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	20.0	23.0	26.6	NA*

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set. 14 April 2022

Discharge and Monitoring Point 5: Discharge water quality monitoring

Dellatent	Unit of		No. of samples	Date samples	Lowest sample	Mean of	Highest sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Continuous	Continuous	NIA	20.0	25.4	20.7	25
Temperature	Celsius	Continuous	Continuous	NA	20.6	25.1	28.7	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	19.0	23.1	28.2	NA*

Comments: n/a

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Continuous	Continuous	NIA	10 F	22.7	26.2	NI A *
Temperature	Celsius	Continuous	Continuous	NA	19.5	22.7	26.2	NA*

Comments: n/a



14 April 2022

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	7/03/2022	<0.001	<0.001	<0.001	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	7/03/2022	0.8	0.8	0.8	NA*
рН	рН	Monthly during discharge	0	7/03/2022	7.4	7.4	7.4	NA*
Total Phosporous - filtered sample	milligrams per litre	Monthly during discharge	0	7/03/2022	0.19	0.19	0.19	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	7/03/2022	12.0	12.0	12.0	NA*
Zinc	micrograms per litre	Monthly during discharge	0	7/03/2022	<0.005	<0.005	<0.005	NA*



14 April 2022

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.5	4.0	4.1	NA
Moisture content	Percent	Continuous	**	NA	7.0	8.0	8.3	NA
Nitrogen oxides	parts per million	Continuous	**	NA	3.2	12.9	19.2	25
Oxygen (O2)	Percent	Continuous	**	NA	13.0	13.2	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	9/11/2021	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	9/11/2021	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	76.3	93.1	98.0	NA
Volatile organic compounds	parts per million	Yearly	1	9/11/2021	-	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	249.4	397.1	437.0	NA

Discharge and Monitoring Point 9: Air emissions monitoring



Notes: * equipment detection limit



14 April 2022

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes: ** Continuous data recorded via inline flow meter