B Monitoring and Complaints Summary

Period: 1/05/2018 to 1/06/2018



18 June 2018

| Pollution Category | Number of Complaints |
|--------------------|----------------------|
| Air | 0 |
| Water | 0 |
| Noise | 0 |
| Waste | 0 |
| Other | 0 |

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&op

tion=licence&searchrange=licence&range=POEO%20licence&prp=no&status

=Issued

B2 Concentration Monitoring Summary

Number of Pollution Complaints

B1

Monitoring Point 2: Effluent quality monitoring

| Pollutant | Unit of Measure | No. of Samples required | No. of samples collected | Date samples collected | Lowest sample value | Mean of sample | Highest sample value | Licence Limit |
|---------------------------|-------------------------|-------------------------------|--------------------------|------------------------|---------------------|----------------|----------------------------|------------------|
| Biochemical oxygen demand | milligrams per litre | Special Frequency 1 | 0 | - | - | - | 1 | 20 |
| Total suspended solids | milligrams per litre | Special Frequency 1 | 0 | - | - | - | - | 30 |

0

Comments: No effluent irrigated this month.

Monitoring Point 4: Ambient water monitoring

| Pollutant | Unit of Measure | | No. of samples collected | Date samples collected | Lowest sample value | Mean of sample | Highest sample value | Licence Limit |
|-------------|--------------------|------------|--------------------------|------------------------|---------------------|----------------|----------------------------|------------------|
| Temperature | Degrees Celsius | Continuous | Continuous | NA | 12.2 | 13.4 | 14.5 | NA* |



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to

receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

18 June 2018

Discharge and Monitoring Point 5: Discharge water quality monitoring

| | | No. of | | | | | Highest | |
|-------------|--------------------|------------|--------------------------|------------------------|---------------------|----------------|-----------------|------------------|
| Pollutant | Unit of Measure | | No. of samples collected | Date samples collected | Lowest sample value | Mean of sample | sample value | Licence Limit |
| Temperature | Degrees Celsius | Continuous | Continuous | NA | 13.2 | 15.1 | 17.9 | 35 |

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

| Pollutant | Unit of Measure | No. of Samples required | No. of samples collected | Date samples collected | Lowest sample value | Mean of sample | Highest sample value | Licence Limit |
|-------------|--------------------|-------------------------------|--------------------------|------------------------|---------------------|----------------|----------------------------|------------------|
| Temperature | Degrees Celsius | Continuous | Continuous | NA | 12.7 | 15.9 | 19.3 | NA* |



18 June 2018

Comments: n/a

Monitoring Point 7: Ambient water monitoring

| | | No. of | | | | | Highest | |
|-------------|---------|------------|----------------|--------------|--------------|---------|---------|---------|
| | Unit of | Samples | No. of samples | Date samples | Lowest | Mean of | sample | Licence |
| Pollutant | Measure | required | collected | collected | sample value | sample | value | Limit |
| | Degrees | Continuous | Cantinuaus | NIA | 12.7 | 16.3 | 10.4 | N1 A * |
| Temperature | Celsius | Continuous | Continuous | NA | 13.7 | 16.2 | 19.4 | NA* |

Comments: n/a

Monitoring Point 8: Discharge water monitoring

| Pollutant | Unit of Measure | No. of Samples required | No. of samples collected | Date samples collected | Lowest sample value | Mean of sample | Highest sample value | Licence Limit |
|--------------|-------------------------|-------------------------------|--------------------------|------------------------|---------------------|----------------|----------------------------|------------------|
| | | Monthly | | | | | | |
| Copper | micrograms per litre | during discharge | 0 | - | - | - | - | NA* |
| Соррег | per ner e | Monthly | | | | | | |
| Nitrogen | milligrams per | during | 0 | - | - | - | - | NA* |
| (total) | litre | discharge | | | | | | |
| | | Monthly | | | | | | |
| | | during | 0 | - | - | - | - | NA* |
| pН | рН | discharge | | | | | | |
| Total | | | | | | | | |
| Phosporous - | | Monthly | 0 | _ | _ | _ | _ | NA* |
| filtered | milligrams per | _ | | | | _ | _ | INA |
| sample | litre | discharge | | | | | | |
| Total | | Monthly | | | | | | |
| suspended | milligrams per | during | 0 | - | - | - | - | NA* |
| solids | litre | discharge | | | | | | |
| | | Monthly | | | | | | |
| | micrograms | during | 0 | - | - | - | - | NA* |
| Zinc | per litre | discharge | | | | | | |



18 June 2018

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to

receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitoring

| | Unit of | No. of Samples | No. of samples | Date samples | Lowest | Mean of | Highest sample | Licence |
|----------------------------------|-------------------------------|----------------|----------------|--------------|--------------|---------|----------------|---------|
| Pollutant | Measure | required | collected | collected | sample value | sample | value | Limit |
| Carbon dioxide | % | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |
| Moisture content | Percent | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |
| Nitric oxide | parts per million | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |
| Nitrogen dioxide | parts per million | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |
| Nitrogen oxides | parts per million | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | 25 |
| Oxygen (O2) | Percent | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |
| Solid particles | milligrams per cubic metre | Yearly | 1 | 6/03/2018 | - | <0.7 | - | 10 |
| Sulphur dioxide | parts per million | Yearly | 1 | 6/03/2018 | - | <1 | - | 3 |
| Temperature | Degrees Celsius | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |
| Volatile organic compounds | parts per million | Yearly | 1 | 6/03/2018 | - | <1 | - | NA |
| Volumetric flow rate | cubic metres per second | Continuous | ** | NA | 0.0 | 0.0 | 0.0 | NA |



Notes: * equipment detection limit

Comments: Some negative NO and NO2 values were recorded during the month. These values have been recorded as zeroes.

Plant was offline for May 2018

Monitoring Point 10: Ambient air monitoring

| Pollutant | Unit of Measure | No. of Samples required | No. of samples collected | Date samples collected | Lowest sample value | Mean of sample | Highest sample value | Licence Limit |
|---------------------|---------------------------------|-------------------------------|--------------------------|------------------------|---------------------|----------------|----------------------------|------------------|
| Nitric oxide | parts per hundred million | Continuous | ** | NA | 0.0 | 0.1 | 4.3 | NA |
| Nitrogen dioxide | parts per hundred million | Continuous | ** | NA | 0.1 | 0.5 | 2.9 | NA |
| Nitrogen oxides | parts per hundred million | Continuous | ** | NA | 0.1 | 0.6 | 5.8 | NA |
| Ozone | parts per hundred million | Continuous | ** | NA | 0.0 | 1.8 | 4.5 | NA |



18 June 2018

Comments:

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

| | | No. of | | | _ | | | |
|-----------|----------------|------------|----------------|--------------|--------|-------------|---------|---------|
| | Unit of | Samples | No. of samples | Date Samples | Lowest | | Highest | Licence |
| Pollutant | Measure | required | collected | collected | result | Mean result | result | Limit |
| | Kilolitres per | Cti | ** | NI A | 0 | 0 | 0 | 100 |
| Sewage | day | Continuous | 4.4. | NA | U | U | U | 100 |

Notes: ** Continuous data recorded via inline flow meter

Comments: No discharge this month.