B Monitoring and Complaints Summary

Period: 1/05/2019 to 1/06/2019



B1 Number of Pollution Complaints 0

5 August 2019

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&op

tion=licence&searchrange=licence&range=POEO%20licence&prp=no&status

=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	-	-	1	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	-	-	30

Comments: No effluent irrigated this month.

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.9	14.0	19.0	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to

receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

5 August 2019

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of					Highest	
Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.8	14.3	19.1	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.8	17.0	20.4	NA*



Comments: n/a 5 August 2019

Monitoring Point 7: Ambient water monitoring

		No. of					Highest	
	Unit of	Samples	No. of samples	Date samples	Lowest	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	sample value	sample	value	Limit
	Degrees	C	Cantina	NIA	11.0	47.2	20.4	N1 A *
Temperature	Celsius	Continuous	Continuous	NA	11.8	17.2	20.4	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per litre	discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



5 August 2019

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to

receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	-	-	-	NA
Moisture content	Percent	Continuous	**	NA	-	-	-	NA
Nitric oxide	parts per million	Continuous	**	NA	-	-	-	NA
Nitrogen dioxide	parts per million	Continuous	**	NA	-	-	-	NA
Nitrogen oxides	parts per million	Continuous	**	NA	-	-	-	25
Oxygen (O2)	Percent	Continuous	**	NA	-	-	-	NA
Solid particles	milligrams per cubic metre	Yearly	1	6/03/2018	-	<0.7	-	10
Sulphur dioxide	parts per million	Yearly	1	6/03/2018	-	<1	-	3
Temperature	Degrees Celsius	Continuous	**	NA	-	-	-	NA
Volatile organic compounds	parts per million	Yearly	1	6/03/2018	-	<1	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	-	-	-	NA



Notes: * equipment detection limit

Comments: Some negative NO and NO2 values were recorded during the month. These values have been recorded as zeroes.

Plant was offline for May 2019



B3 Volume or Mass Monitoring Summary

5 August 2019

Monitoring Point 3: Sewage volume monitoring

		No. of						
	Unit of	Samples	No. of samples	Date Samples	Lowest		Highest	Licence
Pollutant	Measure	required	collected	collected	result	Mean result	result	Limit
	Kilolitres per	Continuous	**	NA	0	0	0	100
Sewage	day	Continuous		INA	U	U	U	100

Notes: ** Continuous data recorded via inline flow meter

Comments: No discharge this month.