

# Monthly Summary Report

EPL Number: 13007  
 EPL Holder: EnergyAustralia NSW  
 EPL Name of facility: MOUNT PIPER POWER STATION  
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847  
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=164117&SYSUID=1&LICID=13007>  
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Period monitored: November 2019  
 Monthly Summary Status: Complete: all monitoring data obtained

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Number of times monitored in month	Min. Value	Mean Value	Median Value	Max. Value	100 Percentile limit	Exceedance	Published Date	Comment	
LDP2	Nitrogen Oxides	g/m3	Continuous during discharge	Continuous d	0.08	0.559	0.52		1	1.5	No	2/3/2020	
LDP1	Oil and Grease	mg/L	Monthly during discharge							10	No	2/3/2020	Not sampled: due to no flow / no discharge.
LDP1	pH	pH	Monthly during discharge								No	2/3/2020	Not sampled: due to no flow / no discharge.
LDP1	Total suspended sol	mg/L	Monthly during discharge								No	2/3/2020	Not sampled: due to no flow / no discharge.
LDP2	Sulphur dioxide	mg/m3	Continuous during discharge	Continuous d	336	1191	1206	1335			No	2/3/2020	
LDP3	Nitrogen Oxides	g/m3	Continuous during discharge	Continuous d	0.06	0.452	0.43	0.81		1.5	No	2/3/2020	Not sampled: due to non-operational facility / unit: 01-12/11/2019; 29-30/11/2019.
LDP3	Sulphur dioxide	mg/m3	Continuous during discharge	Continuous d	322	1166	1188	1297			No	2/3/2020	Not sampled: due to non-operational facility / unit: 01-12/11/2019; 29-30/11/2019.

# Monthly Exceedance Table

EPL Number: 13007  
 EPL Holder: EnergyAustralia NSW  
 EPL Name of facility: MOUNT PIPER POWER STATION  
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847  
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=164117&SYSUID=1&LICID=13007>  
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Period monitored: November 2019

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Sample Value	100 Percentile Limit	Exceedance	Comment
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL

## Monthly Correction Log

EPL Number: 13007  
EPL Holder: EnergyAustralia NSW  
EPL Name of facility: MOUNT PIPER POWER STATION  
EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847  
EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=164117&SYSUID=1&LICID=13007>  
EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
EPL Period monitored: November 2019

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	