B Monitoring and Complaints Summary

Period: 1/10/2020 to 1/11/2020



B1 Number of Pollution Complaints

0

3 November 2020

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	4/08/2020	3	3	3	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	4/08/2020	<5	<5	< 5	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.7	20.3	23.3	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

3 November 2020

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
Pollutant			No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.6	22.2	28.7	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.6	20.7	25.7	NA*



Comments: n/a 3 November 2020

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
	Unit of		No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	C	Cantina	NIA	16.1	20.4	22.4	N1 A *
Temperature	Celsius	Continuous	Continuous	NA	16.1	20.1	23.1	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
рН рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended milli	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



3 November 2020

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month.

Discharge and Monitoring Point 9: Air emissions monitoring

		No. of			Lowest		Highest	
Pollutant	Unit of Measure	Samples	No. of samples collected	Date samples collected	sample value	Mean of	sample value	Licence Limit
Carbon dioxide	%	required Continuous	**	NA	3.7	sample 4.3	4.9	NA
Moisture content	Percent	Continuous	**	NA	7.5	8.5	9.7	NA
Nitrogen oxides	parts per million	Continuous	**	NA	4.4	7.4	13.0	25
Oxygen (O2)	Percent	Continuous	**	NA	12.4	13.3	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	24/07/2020	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	24/07/2020	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	72.7	83.6	92.6	NA
Volatile organic compounds	parts per million	Yearly	1	24/07/2020	-	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	238.0	337.1	439.0	NA



Notes: * equipment detection limit

Comments: n/a



B3 Volume or Mass Monitoring Summary

3 November 2020

Monitoring Point 3: Sewage volume monitoring

		No. of						
	Unit of	Samples	No. of samples	Date Samples	Lowest	Mean	Highest	Licence
Pollutant	Measure	required	collected	collected	result	result	result	Limit
	Kilolitres per	Continuous	**	NA	0	5	24	100
Sewage	day	Continuous		IVA	O	3	24	100

Notes:

** Continuous data recorded via inline flow meter

Comments: