

B Monitoring and Complaints Summary

Period: 1/07/2026 to 31/07/2026

B1 Number of Pollution Complaints 0

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&operation=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>



EnergyAustralia

LIGHT THE WAY

12 August 2026

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	-	-	-	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	-	-	30

Comments: No irrigation, no sample taken

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	13.4	14.4	16.6	NA*



EnergyAustralia
LIGHT THE WAY

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

12 August 2026

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.6	14.5	25.2	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.6	13.7	16.5	NA*

Comments: n/a

12 August 2026

**Monitoring Point 7: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.0	14.2	16.2	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
pH	pH	Monthly during discharge	0	-	-	-	-	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*

Comments: No discharge during this month



EnergyAustralia

LIGHT THE WAY

12 August 2026

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	8.7	9.5	10.0	NA
Nitrogen oxides	parts per million	Continuous	3.2	6.5	8.9	25
Oxygen (O2)	Percent	Continuous	12.2	12.5	13.2	NA
Temperature	Degrees Celsius	Continuous	79.3	85.1	92.4	NA
Volumetric flow rate	cubic metres per second	Continuous	300.2	360.4	402.8	NA

Discharge and Monitoring Point 13: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	10.0	10.0	10.0	NA
Nitrogen oxides	parts per million	Continuous	11.9	12.1	12.6	25
Oxygen (O2)	Percent	Continuous	13.3	13.4	13.5	NA
Temperature	Degrees Celsius	Continuous	632.0	646.3	653.6	NA
Volumetric flow rate	cubic metres per second	Continuous	468.4	539.2	669.3	NA
Velocity	Metres per second	Continuous	38.5	44.0	52.0	NA

Notes: Moisture substituted with conservative 10%

12 August 2026

B3 Volume or Mass Monitoring Summary***Monitoring Point 3: Sewage volume monitoring***

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	-	-	-	100

Notes: ** Continuous data recorded via inline flow meter

Comments: No irrigation this month