

## Monthly Summary Report

EPL Number: 13007  
 EPL Holder: EnergyAustralia NSW  
 EPL Name of facility: MOUNT PIPER POWER STATION  
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847  
 EPL Website link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOlicence.aspx?DOCID=54164&SYSUID=1&LICID=13007>  
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Period monitored: October 2015  
 Monthly Summary Status: Complete: all monitoring data obtained

| Licensed Monitoring Point Code | Pollutant           | Unit of Measure | Monitoring Frequency       | Number of times monitored in month | Min. Value | Mean Value | Median Value | Max. Value | 100 Percentile limit | Exceedance | Published Date | Comment |
|--------------------------------|---------------------|-----------------|----------------------------|------------------------------------|------------|------------|--------------|------------|----------------------|------------|----------------|---------|
| LDP2                           | Carbon dioxide      | %               | Yearly during discharge    | 1                                  | 8.9        | 8.9        | 8.9          | 8.9        | 8.9                  | No         | 8/6/2018       |         |
| LDP2                           | Dry gas density     | kg/m3           | Yearly during discharge    | 1                                  | 1.34       | 1.34       | 1.34         | 1.34       | 1.34                 | No         | 8/6/2018       |         |
| LDP2                           | Moisture content    | %               | Yearly during discharge    | 1                                  | 7.5        | 7.5        | 7.5          | 7.5        | 7.5                  | No         | 8/6/2018       |         |
| LDP2                           | Molecular weight of | g/g mole        | Yearly during discharge    | 1                                  | 29.9       | 29.9       | 29.9         | 29.9       | 29.9                 | No         | 8/6/2018       |         |
| LDP2                           | Nitrogen Oxides     | g/m3            | Quarterly during discharge | 1                                  | 0.442      | 0.442      | 0.442        | 0.442      | 1.5                  | No         | 8/6/2018       |         |
| LDP2                           | Oxygen (O2)         | %               | Yearly during discharge    | 1                                  | 10.2       | 10.2       | 10.2         | 10.2       | 10.2                 | No         | 8/6/2018       |         |
| LDP2                           | Sulphur dioxide     | mg/m3           | Quarterly during discharge | 1                                  | 892        | 892        | 892          | 892        | 892                  | No         | 8/6/2018       |         |
| LDP2                           | Temperature         | oC              | Yearly during discharge    | 1                                  | 109        | 109        | 109          | 109        | 109                  | No         | 8/6/2018       |         |
| LDP2                           | Velocity            | m/s             | Yearly during discharge    | 1                                  | 9          | 9          | 9            | 9          | 9                    | No         | 8/6/2018       |         |
| LDP2                           | Volumetric flowrate | m3/s            | Yearly during discharge    | 1                                  | 330        | 330        | 330          | 330        | 330                  | No         | 8/6/2018       |         |
| LDP3                           | Carbon dioxide      | %               | Yearly during discharge    | 1                                  | 10.2       | 10.2       | 10.2         | 10.2       | 10.2                 | No         | 8/6/2018       |         |
| LDP3                           | Dry gas density     | kg/m3           | Yearly during discharge    | 1                                  | 1.34       | 1.34       | 1.34         | 1.34       | 1.34                 | No         | 8/6/2018       |         |
| LDP3                           | Moisture content    | %               | Yearly during discharge    | 1                                  | 7.2        | 7.2        | 7.2          | 7.2        | 7.2                  | No         | 8/6/2018       |         |
| LDP3                           | Molecular weight of | g/g mole        | Yearly during discharge    | 1                                  | 30.1       | 30.1       | 30.1         | 30.1       | 30.1                 | No         | 8/6/2018       |         |
| LDP3                           | Nitrogen Oxides     | g/m3            | Quarterly during discharge | 1                                  | 0.875      | 0.875      | 0.875        | 0.875      | 1.5                  | No         | 8/6/2018       |         |
| LDP3                           | Oxygen (O2)         | %               | Yearly during discharge    | 1                                  | 8.7        | 8.7        | 8.7          | 8.7        | 8.7                  | No         | 8/6/2018       |         |
| LDP3                           | Sulphur dioxide     | mg/m3           | Quarterly during discharge | 1                                  | 853        | 853        | 853          | 853        | 853                  | No         | 8/6/2018       |         |
| LDP3                           | Temperature         | oC              | Yearly during discharge    | 1                                  | 120        | 120        | 120          | 120        | 120                  | No         | 8/6/2018       |         |
| LDP3                           | Velocity            | m/s             | Yearly during discharge    | 1                                  | 14         | 14         | 14           | 14         | 14                   | No         | 8/6/2018       |         |
| LDP3                           | Volumetric flowrate | m3/s            | Yearly during discharge    | 1                                  | 393        | 393        | 393          | 393        | 393                  | No         | 8/6/2018       |         |
| LMP1                           | Conductivity        | uS/cm           | Monthly during discharge   | 4                                  | 303        | 398        | 395          | 499        | 499                  | No         | 11/11/2015     |         |
| LMP1                           | pH                  | pH              | Monthly during discharge   | 4                                  | 7.8        | 8          | 8            | 8          | 8.1                  | No         | 11/11/2015     |         |
| LMP1                           | Total suspended sol | mg/L            | Monthly during discharge   | 4                                  | 14         | 73.5       | 38.5         | 203        | 203                  | No         | 11/11/2015     |         |

# Monthly Exceedance Table

EPL Number: 13007  
 EPL Holder: EnergyAustralia NSW  
 EPL Name of facility: MOUNT PIPER POWER STATION  
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847  
 EPL Website link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=54164&SYSUID=1&LICID=13007>  
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Period monitored: October 2015

| Sample Date | Licensed Monitoring Point Code | Pollutant | Unit of Measure | Sample Value | 100 Percentile Limit | Exceedance | Comment |
|-------------|--------------------------------|-----------|-----------------|--------------|----------------------|------------|---------|
| NIL         | NIL                            | NIL       | NIL             | NIL          | NIL                  | NIL        | NIL     |

## Monthly Correction Log

EPL Number: 13007  
 EPL Holder: EnergyAustralia NSW  
 EPL Name of facility: MOUNT PIPER POWER STATION  
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847  
 EPL Website link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=54164&SYSUID=1&LICID=13007>  
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>  
 EPL Period monitored: October 2015

| Sample Date | Licensed Monitoring Point Code | Pollutant | Unit of Measure | Original Data | Corrected Data | Date Corrected | Date Originally Published | Reason |
|-------------|--------------------------------|-----------|-----------------|---------------|----------------|----------------|---------------------------|--------|
| NIL         | NIL                            | NIL       | NIL             | NIL           | NIL            | NIL            | NIL                       |        |