

Monthly Summary Report

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <http://app.epa.nsw.gov.au/prpoeoapp/ViewPOELicence.aspx?DOCID=130877&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: September 2018
 Monthly Summary Status: Complete: all monitoring data obtained

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Number of times monitored in month	Min. Value	Mean Value	Median Value	Max. Value	100 Percentile limit	Exceedance	Published Date	Comment
LMP1	Conductivity	uS/cm	Monthly during discharge	4	17900	24850	26250	29000		No	30/10/2018	
LDP2	Nitrogen Oxides	g/m3	Quarterly during discharge						1.5	No	30/10/2018	Sampled: all monitoring data not yet obtained (at time of monthly publishing).
LDP2	Sulphur dioxide	mg/m3	Quarterly during discharge							No	30/10/2018	Sampled: all monitoring data not yet obtained (at time of monthly publishing).
LDP3	Nitrogen Oxides	g/m3	Quarterly during discharge						1.5	No	30/10/2018	Sampled: all monitoring data not yet obtained (at time of monthly publishing).
LDP3	Sulphur dioxide	mg/m3	Quarterly during discharge							No	30/10/2018	Sampled: all monitoring data not yet obtained (at time of monthly publishing).
LMP1	pH	pH	Monthly during discharge	4	7.7	7.9	7.9	8		No	30/10/2018	
LMP1	Total suspended sol	mg/L	Monthly during discharge	4	6	16	14	30		No	30/10/2018	

Monthly Exceedance Table

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=130877&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: September 2018

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Sample Value	100 Percentile Limit	Exceedance	Comment
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL

Monthly Correction Log

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <http://app.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=130877&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: September 2018

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	