

Monthly Summary Report

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=156231&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: February 2019
 Monthly Summary Status: Complete: all monitoring data obtained

Licensed Monitoring Point Code	Pollutant	Unit of Measure	Monitoring Frequency	Number of times monitored in month	Min. Value	Mean Value	Median Value	Max. Value	100 Percentile limit	Exceedance	Published Date	Comment
LDP2	Nitrogen Oxides	g/m3	Continuous during discharge	Continuous d	0.24	0.515	0.46	0.97	1.5	No	12/8/2019	
LDP1	Oil and Grease	mg/L	Monthly during discharge						10	No	10/5/2019	Not sampled: due to no flow / no discharge.
LDP1	pH	pH	Monthly during discharge							No	10/5/2019	Not sampled: due to no flow / no discharge.
LDP1	Total suspended sol	mg/L	Monthly during discharge							No	10/5/2019	Not sampled: due to no flow / no discharge.
LDP2	Sulphur dioxide	mg/m3	Continuous during discharge	Continuous d	756	1212	1215	1283		No	12/8/2019	
LDP3	Nitrogen Oxides	g/m3	Continuous during discharge	Continuous d	0.21	0.538	0.48	1.1	1.5	No	12/8/2019	Not sampled: due to non-operational facility / unit: 11/02/1019.
LDP3	Sulphur dioxide	mg/m3	Continuous during discharge	Continuous d	926	1195	1200	1274		No	12/8/2019	Not sampled: due to non-operational facility / unit: 11/02/1019.

Monthly Exceedance Table

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=156231&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: February 2019

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Sample Value	100 Percentile Limit	Exceedance	Comment
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL

Monthly Correction Log

EPL Number: 13007
 EPL Holder: EnergyAustralia NSW
 EPL Name of facility: MOUNT PIPER POWER STATION
 EPL Address of facility: 350 BOULDER ROAD, PORTLAND, NSW 2847
 EPL Website link: <https://apps.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=156231&SYSUID=1&LICID=13007>
 EPL Monitoring locations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Unit of measure abbreviations: <https://www.energyaustralia.com.au/mt-piper-epa-reports>
 EPL Period monitored: February 2019

Sample Date	Licensed Monitoring Point Code	Pollutant	Unit of Measure	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
NIL	NIL	NIL	NIL	NIL	NIL	NIL	NIL	