



**EnergyAustralia**  
LIGHT THE WAY

**EnergyAustralia Yallourn**

**BUSHFIRE MITIGATION PLAN  
2019 / 2020**

© 2018 Australia, EnergyAustralia Yallourn Pty Ltd

The intellectual property rights in the material included in this document is solely owned by or licensed to EnergyAustralia Yallourn Pty Ltd. This work is copyright. Other than as permitted by law, no part of it may be reproduced, stored in a retrieval system or transmitted in any form or by any process without prior written permission.

## VERSION HISTORY

Version	Date	Author	Reason
1.0	April 2011	Paul Metlikovec	Initial Issue
2.0	September 2011	Otto Stumpf	Changes as a result of advice from ESV
3.0	July 2012	Otto Stumpf	Changes made to accommodate the recommendations from an internal audit conducted in June 2012
3.1	September 2012	Rachel Alexander	Corporate Re-brand and minor formatting changes
4.0	June 2013	Otto Stumpf	Periodic Review
5.0	May 2014	Otto Stumpf	Periodic Review / To meet the new regulations, audit recommendations and broader scope
6.0	May 2015	Otto Stumpf	Periodic Review
7.0	May 2016	Otto Stumpf	Periodic Review
8.0	May 2017	Otto Stumpf	Minor changes to the objective (clause 6), the preventative strategies (clause 8) and clause 9.2/10
8.1	June 2017	Rachel Alexander	Update to References Required
9.0	June 2018	Brad Miller	Periodic Review
<b>10.0</b>	<b>Nov 2019</b>	<b>Brad Miller</b>	<b>Periodic Review</b>
<b>10.1</b>	<b>Dec 2019</b>	<b>Brad Miller</b>	<b>Review to address ESV feedback comments</b>

## AMENDMENTS IN THIS VERSION

No.	Amendment Summary	Amended By
<b>Version 10.0</b>		
1.	Updated Mine Leader & phone number	B. Miller
2.	Updated Section 9.9 Fire Detection to clarify alarm monitoring	P. Gridley
3.	Removed reference to Removal of Vegetation procedure	P. Metlikovec
<b>Version 10.1</b>		
1.	Update Section 9.1 to reference Register of Authorised workers in Maximo	B. Miller

## PURPOSE & SCOPE

<b>WHAT</b>	<p>The objective of the Bushfire Mitigation Plan is to ensure that there are procedures and processes at the Yallourn site to mitigate against the spread of fire that initiates internally as well as the infiltration of external fires. The procedures also mitigate the initiation of bushfires from “at-risk” electrical lines and provide a controlled reduction in fire risk from the site assets.</p> <p>The Bushfire Mitigation Plan must fully comply with the Electricity Safety (Bushfire Mitigation) Regulation. The Bushfire Mitigation Plan must be monitored and audited each year to identify any deficiencies in the plan. The plan must then be updated and formally submitted to Energy Safe Victoria (ESV) before the 1 July of each year.</p>
<b>WHEN</b>	This procedure is to be utilised when the Bushfire Mitigation Plan needs to be implemented, reviewed and updated.
<b>WHO</b>	This procedure shall be followed by all responsible personnel who implement the Bushfire Mitigation Plan and the nominated responsible officer who audits the plan.
<b>WHY</b>	This procedure has been developed to comply with the Electricity Safety (Bushfire Mitigation) Regulation and the requirements of the CFA and Dept of State, Development and Business Innovation. The Bushfire Mitigation Plan must be reviewed annually, updated and checked against the current Electricity Safety (Bushfire Mitigation) Regulation, then sent to ESV before 1 July to ensure compliance with the Regulation.

# TABLE OF CONTENTS

<b>1</b>	<b>CONTACTS .....</b>	<b>4</b>
<b>2</b>	<b>DISTRIBUTION.....</b>	<b>5</b>
<b>3</b>	<b>INTRODUCTION.....</b>	<b>6</b>
<b>4</b>	<b>BUSHFIRE MITIGATION POLICY .....</b>	<b>7</b>
<b>5</b>	<b>DEFINITIONS.....</b>	<b>7</b>
<b>6</b>	<b>OBJECTIVES OF THE PLAN.....</b>	<b>7</b>
6.1	Non EnergyAustralia Overhead Lines.....	8
<b>7</b>	<b>SITE RESPONSIBILITIES .....</b>	<b>8</b>
7.1	Manager Responsibilities.....	8
7.2	Site Management Procedure for the BMP .....	9
7.3	Site Map.....	9
<b>8</b>	<b>PREVENTATIVE STRATEGIES.....</b>	<b>9</b>
<b>9</b>	<b>LIST OF ALL WORKS.....</b>	<b>10</b>
9.1	Electrical Asset Management .....	10
9.2	Wildfire Risk Committee.....	10
9.3	Hot Works .....	11
9.4	Days of Total Fire Ban .....	11
9.5	Investigations.....	11
9.6	Training and Competence.....	11
9.7	External Agencies .....	12
9.8	Fire Management in the Mine .....	12
9.9	Fire Detection.....	12
9.10	Fire Extinguishers .....	13
9.11	Vehicle Authorisation .....	13
9.12	Reticulated Water Fire Suppression System .....	13
9.13	Contractors .....	13
<b>10</b>	<b>MONITORING.....</b>	<b>14</b>
<b>11</b>	<b>AUDITING AND REPORTING.....</b>	<b>14</b>
<b>12</b>	<b>REFERENCES.....</b>	<b>15</b>
<b>13</b>	<b>APPENDIX 1 - SITE AERIAL PHOTOGRAPH.....</b>	<b>16</b>
<b>14</b>	<b>APPENDIX 2 – CROSS REFERENCE TO THE ELECTRICITY SAFETY (BUSHFIRE MITIGATION) REGULATION .....</b>	<b>17</b>

# 1 CONTACTS

<b>Specified Operator</b>	EnergyAustralia Yallourn Pty. Ltd
<b>Office Address</b>	Eastern Road Yallourn, Victoria, 3825
<b>Postal Address</b>	PO Box 444 Moe, Victoria, 3825
<b>Telephone</b>	(03) 5128 2000

<b>Person Responsible for Plan Preparation</b>	Brad Miller	Paul Metlikovec
<b>Position</b>	Mine Maintenance Specialist	Mine Specialist
<b>Office Address</b>	Eastern Road Yallourn Victoria, 3825	
<b>Postal Address</b>	PO Box 444 Moe Victoria, 3825	
<b>Telephone</b>	03 5128 2747	03 5128 2273

<b>Person Responsible for Plan Implementation</b>	Lance Wallace	Paul Gridley
<b>Position</b>	Mine Leader	Estate Services Alliance Leader
<b>Office Address</b>	Eastern Road Yallourn Victoria, 3825	
<b>Postal Address</b>	PO Box 444 Moe Victoria, 3825	
<b>Telephone</b>	03 5128 4040	03 5128 2935

<b>Emergency Contact Number for Immediate Action</b>	For all site emergencies dial: <b>3333</b> (internal) or <b>1800 04 3333</b> (mobile phone or external)
--	---

## 2 DISTRIBUTION

Copies of this document have been issued to:

Energy Safe Victoria

### Copies of Bushfire Mitigation Plan

A hard copy of the Yallourn Bushfire Mitigation Plan will be available at the EnergyAustralia Yallourn principal office; please contact the Office Leader on telephone 5128 2960 for a current copy. Copies of the plan are available to the public for inspection. The EnergyAustralia Yallourn address is Eastern Road Yallourn Vic 3825.

All hard copies will be stamped as uncontrolled.

Electronic copies of the Yallourn Bushfire Mitigation plan can be found on the EnergyAustralia website:

<https://www.energyaustralia.com.au/about-us/energy-generation/yallourn-power-station/ensuring-we-do-right-thing>

### 3 INTRODUCTION

EnergyAustralia Yallourn Pty Ltd is the private owner and operator of the Yallourn W Power Station and the adjacent Yallourn Mine which are located in the Latrobe Valley approximately 150 km's east of Melbourne. EnergyAustralia Yallourn's operations are located within the City of Latrobe; the Power Station, Mine and buffer zones cover some 5,500 hectares. Refer to figure 1 in the Appendix for the boundaries of EnergyAustralia Yallourn.

The Yallourn Mine is one of three large open cut brown coal mines in the Latrobe Valley in Victoria. Mining operations are based on the open cut mining method, using the slope mining method with dozers and feeder breakers to excavate and load sized coal onto conveyors. Overburden operations consist of both auxiliary earthmoving plant and a bucket wheel dredger to excavate the overburden overlying the coal. A series of conveyors are used to transport the overburden material to an internal dump located within a worked-out section of the mine. Coal is transported by a series of conveyors to a 30,000 tonne raw coal bunker, which provides approximately 12 hours coal reserves for the Power Station. The Power Station and the mine operate 24 hours per day, 365 days per year. Yallourn seam coal has high moisture content (65 - 68%); low ash (1.5 - 3.0%) and low energy content (6 - 7 Mega joule/kg (NWSE)).

Mining operations are currently located within Maryvale Field of the Yallourn open cut mine. Coal mining commenced full operational in the Maryvale field from the start of 2015. Worked out sections of the mine are progressively rehabilitated in accordance with an approved Rehabilitation Master Plan, following mining and overburden dumping. This results in progressive shaping and stabilisation of overburden batters and dumps, coal floor coverage and some coal batter coverage. Routine maintenance programs manage the fuel loads in and around the mine areas.

Effective from the 5th September 2002, EnergyAustralia Yallourn established a Mine Alliance contract with Roche Thies Linfox Joint Venture (RTL), for the management and operation of the mine. The Mine Alliance contract includes operations and maintenance activities in the mine. The RTL Joint Venture, now RTL Mining and Earthworks P/L, has developed and implemented a certified SHEQ system for the management of safety, health, environment and quality parameters for all those activities included within the scope of the Mine Alliance contract. The Bushfire Mitigation Plan forms part of EnergyAustralia Yallourn's certified HSSE Management System.

EnergyAustralia Yallourn maintains a high standard of risk management whilst achieving its primary role of coal mining and electricity generation. It operates under certified standards for health, safety and environmental management.

The high inherent risks that bushfires pose to business assets, production, health, safety, and the environment has necessitated the implementation of numerous controls to mitigate the risk of bushfire. Furthermore, a well-trained response team along with fixed reticulated and mobile fire suppression systems provides the resources to control bushfires within the property boundary.

The fire hazard ratings system managed by the Country Fire Authority of Victoria has designated the Yallourn site as a hazardous bushfire risk area in relation to the overhead powerlines and associated legislation.

The bushfire mitigation plan has been developed and implemented to manage the risks to assets (including at risk electric lines) and personnel from bushfires and fires which may initiate within the site itself and those which may initiate externally and infiltrate the mine. EnergyAustralia Yallourn has site plans showing the at-risk electric lines on the site and these are available to Energy Safe Victoria and other regulatory bodies upon request.

## 4 BUSHFIRE MITIGATION POLICY

EnergyAustralia Yallourn, as a specified operator, is committed to managing the site to mitigate against the spread of fire that initiates internally as well as the infiltration of external fires. This includes a commitment to protect at-risk electrical lines in compliance with the Electricity Safety Act and associated Bushfire Mitigation Regulation. This will be achieved by the application of various strategies including:

- Monitoring the actions from the Bushfire Mitigation Plan through the Wildfire Committee
- Periodic inspection
- Proactive operation and maintenance plans
- Monitoring of plant and surrounding environment
- Reporting of fires
- Quick response to the extinguishing of fires
- The provision of firefighting systems, and
- Assisting fire control agencies

## 5 DEFINITIONS

**Bushfire** is defined by CFA Victoria as: “A freely burning, uncontrolled and unplanned fire, which needs to be extinguished. It includes fires in woods or forest, mixtures of scrub, bush and grasslands; or plantation or nursery stock.”

**At-Risk electric line** – means an electrical line (other than private electric line) that is above the surface of land and in a hazardous bushfire risk area.

**Specified operator** – means the operator of an at risk electric line but does not include a major electricity company (transmission or distribution)

## 6 OBJECTIVES OF THE PLAN

The objective of the Bushfire Mitigation Plan is to outline the controls identified in the EnergyAustralia system to reduce the risk of bushfire damage to assets (including at-risk electric lines) and personnel on the Yallourn site from bushfires which may commence within the site itself and those which may commence externally and infiltrate the mine.

This Bushfire Mitigation Plan provides an integrated set of procedures to lead a controlled reduction in fire risk to and from all site assets, through systems of asset inspection and management, fuel reduction, ignition source containment and fire control.

The specific objectives of the Plan are:

- To fully comply with the Electricity Safety Act and Electricity Safety (Bushfire Mitigation) Regulations
- To describe the processes and procedures for monitoring the implementation and effectiveness of the bushfire mitigation strategies and programs for the site.
- To maintain a program of asset inspections consistent with the assessed level of risk

- To operate and maintain the plant and facilities with controls to minimise the risk of initiation and/or spread of fire
- To manage vegetation fuel loads and asset clearances in a timely manner, for minimum fire risk, consistent with relevant standards and regulation
- Assess the performance of programs supporting this Plan and strive for continual improvement
- Communicate with external agencies through the Wildfire Committee

Whilst the effective application of this Plan does lead to reduced fire risk, there is still some residual risk. Consequently there is a need to manage fire response and this is managed under the strategic framework of the site Emergency Response Plan, document SHEMS12-SHE-L01, which states “All fires that have potential to spread beyond the initial point of ignition and all other incidents which may result in a threat to life, or EnergyAustralia Yallourn assets, or the environment are to be considered an emergency and must be immediately reported to applicable statutory combat agencies”.

## 6.1 Non EnergyAustralia Overhead Lines

On the Yallourn site, there are overhead lines owned and managed by others, typically AusNet Services power lines. The AusNet Services power lines are located on easements on the site and are clearly marked on the site drawings. These lines are managed by AusNet Services and the management of these lines is included in their Bushfire Mitigation Plan; hence they are not included in the EnergyAustralia Yallourn Bushfire Mitigation Plan.

There are responsibilities for both EnergyAustralia and AusNet Services to manage the easements in accord with this Plan, the Electrical Safety (Electrical Line Clearance) Plans and with the Yallourn site lease agreement covering the line easements

## 7 SITE RESPONSIBILITIES

### 7.1 Manager Responsibilities

The Mine Leader is responsible to ensure that the Bushfire Mitigation plan is developed, managed and implemented for the Yallourn Mine. The Mine Leader is responsible for the development of SHEMS13-SHE-L04 - Mine Fire Control Management Plan and the management of fuel reduction in the Mine area.

The Mine Manager is responsible for the operation and maintenance of the Mine and the implementation of the SHEMS13-SHE-L04 - Mine Fire Control Management Plan and associated procedures to minimise the bushfire risk in the Mine.

The Estate Services Alliance Manager is responsible for maintaining emergency fire response capability for the site, chairing the Wildfire Risk Committee and developing/implementing procedures applicable to Estate Services to minimise the bushfire risk.

The Mine Specialist and the Electrical Compliance Specialist are responsible for the preparation/update of the Bushfire Mitigation Plan for the Yallourn site.

The Team Engineer Electrical is responsible for the development and implementation of procedures and process for the maintenance and operation of Energy Australia overhead power lines at the Yallourn site.

## 7.2 Site Management Procedure for the BMP

The Station Operating Procedure SHEMS11-SHE-P015 ensures that the Bushfire Mitigation Plan is reviewed annually, updated and checked against the current regulation, then sent to ESV before 1 July to ensure compliance with the Regulation.

## 7.3 Site Map

The site plan shown in the appendix displays the overall area of the Yallourn site. The Mine is a dynamic operation and the overhead lines are re-routed to meet the mining requirements. Single line drawings and layout drawings are continually updated to identify the overhead lines on site. The up to date drawings are available to Energy Safe Victoria upon request but not included as an attachment to this plan.

# 8 PREVENTATIVE STRATEGIES

The preventative strategies to minimise the risk of the 'at-risk' electric lines and other plant starting fires at the Yallourn site are as follows:

- Management of the Mine Fire Control Management Plan
- Management of the overhead reticulation lines by a comprehensive procedure including overhead thermography surveys
- Implement a fuel reduction program prior to and during the fire season
- Manage all hot works on the site
- Manage the specific requirements of hot works on days of total fire bans
- Manage the firefighting equipment on site
- Maintain a process to ensure vehicles and mobile plant are suitably equipped and modified to enter a fuel rich environment
- Manage a process to detect, report and extinguish fires in or near the Yallourn site
- Maintain an emergency response procedure for the site
- Maintain and manage a reticulated water fire suppression system to provide a source of water to effectively extinguish fires
- Assist fire control agencies in the management and investigation of fires on and off site.
- Manage and maintain an effective communication system
- Use trained and competent personnel to implement the bushfire mitigation plan
- No smoking policy in the Mine

Managers across the site have been allocated specific responsibilities to enact the above preventative strategies. A list of the relevant site procedures is tabled in section 12 REFERENCES

The Bushfire Mitigation Plan includes fire hazard removal as well as the preparation of strategic fire breaks to ensure that the Power Station, Mine and other critical assets are protected against bushfire that occur on or external to the EnergyAustralia Yallourn property.

## 9 LIST OF ALL WORKS

### 9.1 Electrical Asset Management

The Mine procedure YMA-OPS- PR-0374 - “Management of LV & HV Overhead Distribution System” documents and details the management of the site’s high and low voltage overhead reticulation system. The document covers the design, maintenance and vegetation management methods for the site.

EnergyAustralia Yallourn maintains an Electrical Safety (Electrical Line Clearance) Plan (SHEMS11-SHE-L01) which provides an integrated set of procedures for the safe management of electrical line clearance and this plan links with the Bushfire Mitigation Plan.

The Mine Alliance maintains electrical assets by completing regular pole earth grid testing, thermography surveys, annual vegetation inspection and clearance, visual pole inspection, regular testing of substation transformer and 3 yearly pole integrity testing using form YMA-OPS-FO-0339 – “Pole Inspection / New Pole / Pole Removal Data Sheet”. The frequency of these tests, inspections and checks are defined in the procedure for the Management of LV & HV Overhead Distribution. Only personnel who possess the relevant competency can carry out maintenance on or near electrical assets at Yallourn. Site personnel and contractors who carry out work and inspections on or near at –risk electric lines will have completed the approved training and comply with site procedures. For online asset inspections this means a linesman qualification; for vegetation inspections a Certificate 2 in Asset Inspection 22109VIC or equivalent. A register of authorised workers is maintained within the Maximo Asset Management system to ensure that workers have the appropriate qualifications prior to inspections or work on or near electric lines, and to monitor when refresher training is required. Refer report YXADM0088 - Register of Authorized Workers.

All new overhead power line installations are designed to meet the site Electrical Safety Management Scheme and the regulator’s installation standards.

On days of high fire danger the switching of overhead power lines is minimised. Electrical operators pay particular attention to survey the area surrounding each pole switch for hot embers after switching has been completed.

On days of total fire ban all work on overhead power lines is postponed and emergency switching is carried out under Mine procedure YMA-OPS-PR-0129 - “Carrying out Hot Works on Days of Total Fire Ban”.

In the event of a fire threatening the Yallourn site, the Site Emergency Response Plan is initiated.

All substations have fire detection and suppression monitoring systems. These are checked as part of a monthly routine by a competent contractor.

### 9.2 Wildfire Risk Committee

The Estate Service Alliance manages the Wildfire Risk Committee to coordinate the fuel reduction works across the site. The Wildfire Risk Committee meets monthly, reviews the condition on site, monitors the implementation of the Bushfire Mitigation Plan and implements action to ensure that the EnergyAustralia Yallourn site is adequately protected against wildfire attack. A specific focus is placed on fire risk mitigation by the committee during the fire danger period

The Wildfire Risk Committee includes representatives from the Latrobe Shire, Ausnet, Vic roads, V/line and the professional grazing company to discuss and monitor the fire mitigation actions particularly during the fire danger period.

Fire hazard removal works include slashing, mulching, pruning and controlled fuel reduction burns. These works are assessed prior to each fire season, when a program is established and enacted. Regular inspections during progress of works are conducted to maintain hazard reduction priorities and report to management.

EnergyAustralia Yallourn has a lease with a professional grazing company over extensive perimeter lands as well as strategic areas within the Mine. The conditions of the lease require cooperation on grass fuel reduction for the annual fire season. A representative from the professional grazing company, Minto participates in the Wildfire Risk Committee meeting.

### 9.3 Hot Works

All hot works on the site are managed according to specific procedures.

In the Mine, procedure YMA-OPS-PR-0343 - Hot Works Procedure, provides the methodology for the undertaking of hot works within the mine. Hot Work Permits are issued for all hot works carried out in the Mine. The Issuing Authority advises personnel of all restrictions that may apply to hot works, including the non-issue of Hot Work Permits on high risk days. Restrictions are in place for the issuing of Hot Works Permits on days of total fire ban and internal fire alerts are controlled through this procedure.

The Power Station controls the instruction Hot Works SHEMS11-SHE-P500-I01 to manage all hot works on the Power Station site for general conditions and for days of total fire ban.

### 9.4 Days of Total Fire Ban

The Standard Operating Procedure for Applying for CFA Permits and Internal Permits to Carry Out Hot Works on Days of Total Fire Ban SHEMS11-SHE-P001 defines the process for obtaining a total fire ban exemption for essential works.

Mine procedure YMA-OPS-PR-0129 - "Carrying out Hot Works on Days of Total Fire Ban", must be followed if hot work needs to be done in the Mine on a total fire ban day. The procedure YMA-OPS-PR-0217 – "Control Centre Fire Alert" details the actions to be taken by the Control Centre when a Fire Alert is declared.

Additional resources are provided on site when the CFA declare a 'Day of extreme fire danger'.

### 9.5 Investigations

An investigation will be initiated in the event of a fire involving Yallourn's at-risk electrical lines. The investigation will use the site's investigation procedures to identify the cause of the fire and the actions required to reduce the risk of further occurrences of the incident. All fires originating from Yallourn's supply network will be reported to Energy Safe Victoria in accordance with the Electrical Safety Management Scheme.

### 9.6 Training and Competence

All personnel required to perform tasks detailed in this procedure are trained to the requirements defined in the site procedures, industry standard and legislation. The training of personnel is managed and recorded by training coordinators in the Mine and Power Station. All personnel carrying out work on site are fully site inducted. The induction process states the minimum requirements for carrying out work on site, the need to report fires and provide firefighting assistance within their capabilities.

All electrical operators are trained to the relevant site's procedures and competent to perform the electrical switching. All personnel carrying out maintenance work on electrical assets in the Mine are trained and competent for this work.

Site procedure SHEMS11-SHE-P502-I03 – Authorisation to perform electrical work on site, defines the process to register all authorised electrical workers for the site and ensure the competency of electrical workers.

Relevant managers on site are trained on the Australasian Inter-Service Incident Management System (AIIMS) to ensure effective incident management on site,

## 9.7 External Agencies

The Emergency Response Plan defines the function and responsibilities of the incident management team and the interface with emergency services and external agencies. Reporting to external agencies is done in accordance with the EnergyAustralia document SHEMS15-SHE-P001-A02 - Quick Guide - Immediate Incident Reporting. Yallourn provides assistance to fire control authorities, as required, in the investigation of fires on site.

## 9.8 Fire Management in the Mine

EnergyAustralia has developed a Mine Fire Control Management Plan (FCMP). The FCMP forms an integral component of EnergyAustralia Yallourn's SHE Management System and provides the framework, procedures and processes to effectively manage fire related hazards. The objectives of the FCMP are to ensure that effective processes and procedures are established, implemented and maintained to enable the effective management of fire related hazards at Yallourn Mine.

In particular, a key objective of the FCMP is to control and minimise any impact from a mine fire on the environment, public and employee safety and health, mine assets and continuity of coal supply.

In summary, the key objectives include:

- Provide the systems and processes to effectively manage the risk associated with a mine fire that could be sourced from either within the mine or external to the mine;
- Ensure public safety and health is effectively maintained;
- Minimise the impact of fire on the surrounding environment;
- Ensure public infrastructure is not adversely impacted including for example: roads, railway lines, rivers, power infrastructure, etc.;
- Maintain a safe working environment for all employees, contractors and stakeholders;
- Maintain continuity of operations, including infrastructure associated with coal supply and overburden removal;
- Comply with all relevant legal and other requirements;
- Maintain an environment of continuous improvement.

## 9.9 Fire Detection

Fire detection and alarms systems are used throughout the site. These systems provide early detection of fires and ensure that emergency services respond to the alarm. Alarms from the fire suppression and detection systems throughout the Yallourn site are monitored in the Mine Control Room.

The Emergency and Protective Services Team responds to all Power Station alarms and arrange for CFA back up where an actual fire is detected. Alarm systems are routinely tested for functionality and defects repaired promptly by Estate Services to the standard set in AS 1851-2012.

Mine procedure YMA-OPS-PR-0100 - Fire Procedure, details the actions required of all personnel working in the Yallourn Mine in relation to prevention, reporting and fighting of fires in or near the Mine.

## 9.10 Fire Extinguishers

Fire extinguishers are maintained and managed on site. In the Mine, procedure YMA-OPS-PR-0154 details the Mine Manager's responsibility to ensure adequate numbers and types of extinguishers are located and easily identified throughout the Mine.

## 9.11 Vehicle Authorisation

Vehicles used in the Mine must be suitably equipped to enter a fire risk environment. Vehicles are not permitted to enter the Mine unless they have been inspected using form YMA-OPS-FO-0309 - Vehicle Authorisation Inspection and are authorised to enter the Mine. All vehicles are inspected by a competent person before authorised for use on site.

## 9.12 Reticulated Water Fire Suppression System

The fire service pipes, sprays and pumps system undergoes a structured maintenance program based on inspection. This includes;

- Routine inspections completed every 6 months
- Thorough inspections completed every 12 months

Actions from these inspections, and any other daily or weekly routines, are raised as work orders and given a priority ranking which determines when specific works must be completed,

## 9.13 Contractors

Contractors engaged in overhead line maintenance, installation, line clearance (both linesmen and vegetation control companies) must be licensed, trained and competent for the task. Contractors are monitored and audited in the conduct of these works.

All contractors are directly engaged by Energy Australia to maintain and install electrical assets

Vegetation control companies inspect overhead conductors on a twice-yearly basis and clear any vegetation approaching the minimum distances. Should any vegetation breach the minimum distances or contact the conductors then the line is isolated and work is carried out under permit conditions. The minimum approach distance on site exceeds the regulations guidelines. i.e minimum approach distance to overhead lines is set as 5 meters.

## 10 MONITORING

The Wildfire Risk Committee monitors the actions raised by the Committee to ensure that the EnergyAustralia Yallourn site is adequately protected against wildfire attack. The Committee has external representation who provide input to the meeting from a wide viewpoint to assist in the development and implementation of strategies to minimise the fire risk on site. The Mine Maintenance Specialist also monitors the fire mitigation strategies for the Mine and updates the Fire Control Management Plan as required.

## 11 AUDITING AND REPORTING

The Bushfire Mitigation Plan is audited on an annual basis. The audit process is initiated in March of every year by a work order in the site's computerised maintenance management system (Maximo). The prevention maintenance plan MHVRP410E and job plan MHVR410E defines the objectives and specifics of the audit

The audit includes the following;

- Review the Electrical Safety (Electrical Line Clearance) Plan
- Monitor and audit the implementation of the Bushfire Mitigation Plan (this plan)
- Identify any deficiencies in the plan or the implementation
- Monitor and audit the effectiveness of inspections under the plan
- Propose improvements for the plan and the plan's implementation
- Ensure any necessary training for the performance of the plan has been carried out
- Monitor and audit the competence of persons assigned to carry out the inspections

The audit must address the issues identified in clause 6(n) of the Electricity Safety (Bushfire Mitigation) Regulation. Any deficiencies found within the monitoring and auditing process triggers an action, which will be remedied by establishing improvements to the plan.

The revised Bushfire Mitigation Plan is then approved by the Head of Yallourn and sent to Energy Safe Victoria before July each year.

## 12 REFERENCES

Document ID	Document Title
<a href="#">A1039749</a>	SHEMS11-SHE-P015 - Management of the EnergyAustralia Yallourn Bushfire Mitigation Plan
<a href="#">A1039787</a>	SHEMS11-SHE-L01 - Electricity Safety (Electrical Line Clearance) Plan
<a href="#">A1065137</a>	SHEMS13-SHE-L04 - Mine Fire Control Management Plan (FCMP)
<a href="#">A1044340</a>	SHEMS11-SHE-P500-I01 - Hot Works (Power Station)
<a href="#">A1037878</a>	SHEMS10-SHE-P001 - Removal of Vegetation on the EnergyAustralia Yallourn Site
<a href="#">A1017664</a>	SHEMS12-SHE-L01 - Emergency Response Plan
<a href="#">A1031727</a>	SHEMS11-SHE-P001 - Applying for CFA Permits and Internal Permits to Carry Out Hot Works on Days of Total Fire Ban
<a href="#">A1034365</a>	SHEMS11-SHE-P502-I03 – Authorisation to Perform Electrical Work on Site
<a href="#">A1044935</a>	SHEMS11-SHE-P502-R01 - Register of Authorised Electrical Workers
<a href="#">A1034637</a>	YMA-OPS-PR-0374 - Management of LV & HV Overhead Distribution System
<a href="#">A1031477</a>	YMA-OPS-PR-0129 - Carrying Out Hot Works on Days of Total Fire Ban
<a href="#">A1042354</a>	YMA-OPS-PR-0100 - Fire Procedure
<a href="#">A1032855</a>	YMA-OPS-PR-0343 - Hot Works Procedure
<a href="#">A1044137</a>	YMA-OPS-PR-0217 - Control Centre Fire Alert
<a href="#">A1031300</a>	YMA-OPS-PR-0154 - Fire Precautions
<a href="#">A1036207</a>	YMA-OPS-FO-0309 - Vehicle Authorisation Inspection
<a href="#">A1049221</a>	YMA-OPS-FO-0339 - Pole Inspection / New Pole / Pole Removal Data Sheet
<a href="#">A1030405</a>	SHEMS15-SHE-P001 Reporting, Investigation and Classifying Incidents
<a href="#">A1034223</a>	SHEMS11-ESV-P001 - Wildfire Risk Mitigation
N/A	Electricity Safety Act 1998
N/A	Electricity Safety (Bushfire Mitigation) Regulations 2013

# 13 APPENDIX 1 - Site Aerial Photograph




Figure 1 - Aerial Photograph of the EnergyAustralia Yallourn Site - Property Boundary Highlighted in Green

## 14 APPENDIX 2 – Cross reference to the Electricity Safety (Bushfire Mitigation) Regulation

EA Yallourn BMP cross reference to the regulation		
Regulation reference number	Prescribed particulars for bushfire mitigation plans—specified operators - Regulation	Yallourn BMP
6a	the name, address and telephone number of the specified operator	Page 4
6b	the position, address and telephone number of the person who was responsible for the preparation of the plan	Page 4
6c	the position, address and telephone number of the persons who are responsible for carrying out the plan	Page 4
6d	the telephone number of the specified operator's control room so that persons in the room can be contacted in an emergency that requires action by the specified operator to mitigate the danger of bushfire;	Page 4
6e	the bushfire mitigation policy of the specified operator to minimize the risk of fire ignition from its at-risk electric lines	Page 7, Sect. 4
6f	the objectives of the plan to achieve the mitigation of fire danger arising from the specified operator's at-risk electric lines	page 7, Sect. 6
6g	a description, map or plan of the land to which the bushfire mitigation plan applies, identifying the location of the specified operator's at-risk electric lines	page 9, Sect. 7.3
6h	the preventative strategies and programs to be adopted by the specified operator to minimize the risk of the specified operator's at-risk electric lines starting fires	Page 9, Sect. 8
6i	a plan for inspection that ensures that all of the specified operator's at-risk electric lines are inspected at regular intervals of no longer than 37 months	Page 10, Sect. 9.1
6j	details of the processes and procedures for ensuring that each person who is assigned to carry out the inspections referred to in paragraph (i) has satisfactorily completed a training course approved by Energy Safe Victoria and is competent to carry out such inspections	Page 10, Sect. 9.1
6k	details of the processes and procedures for ensuring that persons (other than persons referred to in paragraph (j)) who carry out or will carry out functions under the plan are competent to do so	Page 9, Sect. 9.1 Page 11, Sect. 9.6
6l	the operation and maintenance plans for the specified operator's at-risk electric lines—	
6l (i)	in the event of a fire; and	Page 10, Sect. 9.1 Page 12, Sect. 9.8
6l (ii)	during a total fire ban day; and	Page 11, Sect. 9.4
6l (iii)	during a fire danger period	Page 10, Sect. 9.2
6m	the investigations, analysis and methodology to be adopted by the specified operator for the mitigation of the risk of fire ignition from its at-risk electric lines	Page 11, Sect. 9.5
6n	details of the processes and procedures by which the specified operator will	
6n (i)	monitor the implementation of the bushfire mitigation plan; and	Page 10, Sect. 9.2
6n (ii)	audit the implementation of the plan	Page 14, Sect. 11
6n (iii)	identify any deficiencies in the plan or the plan's implementation	Page 14, Sect. 11
6n (iv)	change the plan and the plan's implementation to rectify any deficiencies identified under subparagraph (iii);	Page 14, Sect. 11
6n (v)	monitor the effectiveness of inspections carried out under the plan; and	Page 14, Sect. 11
6n (vi)	audit the effectiveness of inspections carried out under the plan	Page 14, Sect. 11
6 (o)	the policy of the specified operator in relation to the assistance to be provided to fire control authorities in the investigation of fires near the specified operator's at-risk electric lines	Page 12, Sect. 9.7