

B Monitoring and Complaints Summary

Period: 1/08/2020 to 1/09/2020



EnergyAustralia
LIGHT THE WAY

B1 Number of Pollution Complaints 0

17 September 2020

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

B2 Concentration Monitoring Summary***Monitoring Point 2: Effluent quality monitoring***

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	4/08/2020	3	3	3	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	4/08/2020	<5	<5	<5	30

Comments:

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.2	13.8	16.7	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

17 September 2020

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.8	15.3	22.2	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	10.7	14.2	17.8	NA*

Comments: n/a



EnergyAustralia
LIGHT THE WAY

17 September 2020

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.1	14.0	16.8	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	1	11/08/2020	0.007	0.007	0.007	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	1	11/08/2020	4.0	4.0	4.0	NA*
pH	pH	Monthly during discharge	1	11/08/2020	6.6	6.6	6.6	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	1	11/08/2020	0.38	0.38	0.38	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	1	11/08/2020	13.0	13.0	13.0	NA*
Zinc	micrograms per litre	Monthly during discharge	1	11/08/2020	0.008	0.008	0.008	NA*

Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments:



EnergyAustralia

LIGHT THE WAY

17 September 2020

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.7	4.4	4.7	NA
Moisture content	Percent	Continuous	**	NA	7.4	8.7	9.3	NA
Nitrogen oxides	parts per million	Continuous	**	NA	4.6	9.3	15.6	25
Oxygen (O2)	Percent	Continuous	**	NA	12.9	13.2	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	24/07/2020	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	24/07/2020	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	66.7	83.2	90.6	NA
Volatile organic compounds	parts per million	Yearly	1	24/07/2020	-	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	224.8	382.3	466.2	NA

Notes: * equipment detection limit

Comments: n/a

**EnergyAustralia**

LIGHT THE WAY

17 September 2020



EnergyAustralia
LIGHT THE WAY

17 September 2020

B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	6	23	100

Notes: ** Continuous data recorded via inline flow meter

Comments: