# **B** Monitoring and Complaints Summary

Period: 1/11/2022 to 1/12/2022



# B1 Number of Pollution Complaints

0

11 January 2023

<b>Pollution Category</b>	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

### **B2** Concentration Monitoring Summary

### Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	6/09/2022	<2	<2	<2	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	6/09/2022	16	16	16	30

Comments: No smpling completed this month.

#### Energy Australia Tallawarra EPL Data

#### Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.4	20.6	24.3	NA*



Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

11 January 2023

### Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
	Unit of		No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Continuous	Cantinuaus	NIA	14.4	10.0	26.4	25
Temperature	Celsius	Continuous	Continuous	NA	14.4	19.8	26.4	35

Comments: Periods where the plant is offline have been removed from this data set.

#### Energy Australia Tallawarra EPL Data

# **Monitoring Point 6: Ambient water monitoring**

Pollutant	Unit of Measure	· •	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	15.2	20.9	25.1	NA*



11 January 2023

# **Monitoring Point 7: Ambient water monitoring**

		No. of			Lowest		Highest	
Pollutant			No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	16.0	20.9	24.3	NA*

Comments: n/a

Comments: n/a

# **Monitoring Point 8: Discharge water monitoring**

	T	INo. of	I	1	Lowest	I	Highest	1
			No of sometime	D-4			_	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
		Monthly						
	micrograms	during	1	8/11/2022	0.002	0.002	0.002	NA*
Copper	per litre	discharge						
		Monthly						
Nitrogen	milligrams per	during	1	8/11/2022	2.40	2.40	2.40	NA*
(total)	litre	discharge						
		Monthly						
		during	1	8/11/2022	7.30	7.30	7.30	NA*
pН	рН	discharge						
Total								
Phosporous -		Monthly		- 1 1				
filtered	milligrams per	during	1	8/11/2022	1.16	1.16	1.16	NA*
sample	litre	discharge						
Total		Monthly						
suspended	milligrams per	during	1	8/11/2022	61	61	61	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	1	8/11/2022	<0.005	<0.005	<0.005	NA*
Zinc	per litre	discharge						



11 January 2023

Notes:

\*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments:

# Discharge and Monitoring Point 9: Air emissions monitoring

	1	No. of		1	Lowest	1	Highest	1
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
Carbon dioxide	%	Continuous	**	NA	3.5	6.3	3.5	NA
Moisture content	Percent	Continuous	**	NA	6.9	12.9	44.0	NA
Nitrogen oxides	parts per million	Continuous	**	NA	6.5	9.3	11.1	25
Oxygen (O2)	Percent	Continuous	**	NA	12.7	13.1	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	9/11/2021	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	9/11/2021	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	77.2	90.3	95.5	NA
Volatile organic compounds	parts per million	Yearly	1	9/11/2021	-	0.0079	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	248.8	374.1	414.2	NA



Notes: \* equipment detection limit

Comments: n/a



# **B3** Volume or Mass Monitoring Summary

11 January 2023

# Monitoring Point 3: Sewage volume monitoring

		No. of						
	Unit of	Samples	No. of samples	Date Samples	Lowest	Mean	Highest	Licence
Pollutant	Measure	required	collected	collected	result	result	result	Limit
	Kilolitres per	Continuous	**	NA	0	2	59	100
Sewage	day	Continuous		IVA	O	5	39	100

Notes:

\*\* Continuous data recorded via inline flow meter

Comments: