B Monitoring and Complaints Summary

Period: 1/09/2023 to 1/10/2023



24 October 2023

B1 Number of Pollution Complaints

Pollution CategoryNumber of ComplaintsAir0Water0Noise0Waste0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&o

ption=licence&searchrange=licence&range=POEO%20licence&prp=no&stat

us=Issued

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	4/08/2023	4	4	4	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	4/08/2023	22	22	22	30

0

0

Comments:

Other

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	15.7	20.2	22.7	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply

to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

24 October 2023

Discharge and Monitoring Point 5: Discharge water quality monitoring

		No. of			Lowest		Highest	
	Unit of		No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Continuous	Combinuous	NIA	15.2	10.0	22.0	25
Temperature	Celsius	Continuous	Continuous	NA	15.3	19.0	23.8	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.6	18.5	23.0	NA*



24 October 2023

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
Pollutant	Unit of Measure		No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.7	18.6	22.9	NA*

Comments: n/a

Comments: n/a

Monitoring Point 8: Discharge water monitoring

	T	No. of	1		Lowest	1	Highest	1
	linit of		No of somelos	Data samulas		Mannaf		Licomos
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Copper	per litre	discharge						
		Monthly						
Nitrogen	milligrams per	during	0	-	-	-	-	NA*
(total)	litre	discharge						
		Monthly						
		during	0	-	-	-	-	NA*
pН	рН	discharge						
Total								
Phosporous -		Monthly	_					
filtered	milligrams per	during	0	-	-	-	-	NA*
sample	litre	discharge						
Total		Monthly						
suspended	milligrams per	during	0	-	_	-	-	NA*
solids	litre	discharge						
		Monthly						
	micrograms	during	0	-	-	-	-	NA*
Zinc	per litre	discharge						



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply

to receiving waters

Comments: No discharge this month

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.7	4.1	4.3	NA
Moisture content	Percent	Continuous	**	NA	7.5	8.3	8.5	NA
Nitrogen oxides	parts per million	Continuous	**	NA	8.4	10.7	14.5	25
Oxygen (O2)	Percent	Continuous	**	NA	13.0	13.2	13.9	NA
Solid particles	milligrams per cubic metre	Yearly	1	6/12/2022	-	<0.6	-	10
Sulphur dioxide	parts per million	Yearly	1	6/12/2022	-	1.9	-	3
Temperature	Degrees Celsius	Continuous	**	NA	78.0	89.5	100.9	NA
Volatile organic compounds	parts per million	Yearly	1	6/12/2022	1	<1	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	253.7	372.3	417.1	NA



Notes: * equipment detection limit

Comments: n/a



B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

24 October 2023

		No. of						
Pollutant	Unit of Measure		No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	13	71	100

Notes:

** Continuous data recorded via inline flow meter

Comments: