



**EnergyAustralia**  
LIGHT THE WAY

## B Monitoring and Complaints Summary

Period: 1/01/2024 to 1/02/2024

### B1 Number of Pollution Complaints 0

13 February 2024

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW

Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555!ption=licence&searchrange=licence&range=POEO%20licence&pus=Issued>

### B2 Concentration Monitoring Summary

#### *Monitoring Point 2: Effluent quality monitoring*

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	9/01/2024	3	3	3	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	9/01/2024	23	23	23	30

Comments:

**Monitoring Point 4: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	23.4	25.0	27.8	NA*



Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

13 February 2024

**Discharge and Monitoring Point 5: Discharge water quality monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	20.6	23.1	29.0	35

Comments: Periods where the plant is offline have been removed from this data set.

**Monitoring Point 6: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	22.1	25.0	28.4	NA*

Comments: n/a



**EnergyAustralia**  
LIGHT THE WAY

13 February 2024

**Monitoring Point 7: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	22.1	24.7	27.6	NA*

Comments: n/a

**Monitoring Point 8: Discharge water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
pH	pH	Monthly during discharge	0	-	-	-	-	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*

Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments:



**EnergyAustralia**

LIGHT THE WAY

13 February 2024

**Discharge and Monitoring Point 9: Air emissions monitoring**

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	7.8	8.2	8.5	NA
Nitrogen oxides	parts per million	Continuous	8.5	12.9	18.7	25
Oxygen (O2)	Percent	Continuous	13.1	13.4	13.7	NA
Temperature	Degrees Celsius	Continuous	82.9	86.9	94.3	NA
Volumetric flow rate	cubic metres per second	Continuous	281.3	320.8	402.2	NA



**EnergyAustralia**

LIGHT THE WAY

13 February 2024

**Discharge and Monitoring Point 13: Air emissions monitoring**

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	N/A	N/A	N/A	NA
Nitrogen oxides	parts per million	Continuous	N/A	N/A	N/A	25
Oxygen (O2)	Percent	Continuous	N/A	N/A	N/A	NA
Temperature	Degrees Celsius	Continuous	N/A	N/A	N/A	NA
Velocity	Meters per second	Continuous	N/A	N/A	N/A	NA
Volumetric flow rate	cubic metres per second	Continuous	N/A	N/A	N/A	NA

Notes: Plant not in operation

Comments: N/A Not Applicable Plant Not in Operation



**EnergyAustralia**  
LIGHT THE WAY

13 February 2024

### B3 Volume or Mass Monitoring Summary

#### *Monitoring Point 3: Sewage volume monitoring*

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	11	70	100

Notes: \*\* Continuous data recorded via inline flow meter

Comments:

2530

[&id=555&o  
rp=no&stat](#)

Energy Australia Tallawarra EPL Data

November 2023



Energy Australia Tallawarra EPL Data

November 2023

Energy Australia Tallawarra EPL Data

November 2023

Energy Australia Tallawarra EPL Data

November 2023