



**EnergyAustralia**  
LIGHT THE WAY

## B Monitoring and Complaints Summary

Period: 1/02/2025 to 1/03/2025

### B1 Number of Pollution Complaints 0

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555

Licensee's name: ENERGYAUSTRALIA TALLAWARRA

Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530

Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&operation=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

7 May 2025

### B2 Concentration Monitoring Summary

#### *Monitoring Point 2: Effluent quality monitoring*

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	0	-	-	-	-	20
Total suspended solids	milligrams per litre	Special Frequency 1	0	-	-	-	-	30

Comments: No irrigation

**Monitoring Point 4: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	24.2	26.6	28.0	NA*



Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

7 May 2025

**Discharge and Monitoring Point 5: Discharge water quality monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	19.3	23.7	28.3	35

Comments: Periods where the plant is offline have been removed from this data set.

**Monitoring Point 6: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	22.7	26.4	30.2	NA*

Comments: Data not available between 14 Feb to 26 Feb due to equipment failure



**EnergyAustralia**  
LIGHT THE WAY

7 May 2025

**Monitoring Point 7: Ambient water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	21.6	25.3	28.2	NA*

Comments: n/a

**Monitoring Point 8: Discharge water monitoring**

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
pH	pH	Monthly during discharge	0	-	-	-	-	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*

Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments: No discharge



**EnergyAustralia**  
LIGHT THE WAY

7 May 2025

**Discharge and Monitoring Point 9: Air emissions monitoring**

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	7.9	8.8	9.7	NA
Nitrogen oxides	parts per million	Continuous	2.1	4.4	9.7	25
Oxygen (O2)	Percent	Continuous	12.2	13.0	13.8	NA
Temperature	Degrees Celsius	Continuous	79.9	87.7	97.9	NA
Volumetric flow rate	cubic metres per second	Continuous	225.0	299.7	390.4	NA

**Discharge and Monitoring Point 13: Air emissions monitoring**

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	10.0	10.0	10.0	NA
Nitrogen oxides	parts per million	Continuous	10.1	13.1	16.9	25
Oxygen (O2)	Percent	Continuous	13.1	13.3	13.6	NA
Temperature	Degrees Celsius	Continuous	639.8	646.0	653.4	NA
Velocity	Meters per second	Continuous	37.1	48.0	58.8	NA
Volumetric flow rate	cubic metres per second	Continuous	328.1	428.7	529.0	NA

Notes: Moisture content substituted for conservative value of 10%



**EnergyAustralia**

LIGHT THE WAY

7 May 2025

7 May 2025

**B3 Volume or Mass Monitoring Summary*****Monitoring Point 3: Sewage volume monitoring***

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	0	0	100

Notes: \*\* Continuous data recorded via inline flow meter

Comments: No discharge