



B Monitoring and Complaints Summary

Period: 1/09/2025 to 1/10/2025

B1 Number of Pollution Complaints 0

14 October 2025

Pollution Category	Number of Complaints
Air	0
Water	0
Noise	0
Waste	0
Other	0

EPL Number: 555
 Licensee's name: ENERGYAUSTRALIA TALLAWARRA
 Licensee's address: Tallawarra Power Station, Princes Highway, YALLAH, NSW 2530
 Link to EPL: <http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&option=licence&searchrange=licence&range=POEO%20licence&prp=no&status=Issued>

B2 Concentration Monitoring Summary

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	16/09/2025	6	6	6	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	16/09/2025	14	14	14	30

Comments: Irrigation prior to 6/09/25 covered under June sample. All irrigation post 6/09/25 covered by above sample.

Monitoring Point 4: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	13.8	17.4	21.6	NA*



Notes: *Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC Guidelines apply to receiving waters

Comments: Periods where the plant is offline or Thermoshock is active have been removed from this data set.

14 October 2025

Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.8	18.5	24.1	35

Comments: Periods where the plant is offline have been removed from this data set.

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.9	17.4	20.8	NA*

Comments: n/a



14 October 2025

Monitoring Point 7: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	14.4	17.6	20.8	NA*

Comments: n/a

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
pH	pH	Monthly during discharge	0	-	-	-	-	NA*
Total Phosphorous - filtered sample	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*

Comments:



14 October 2025

Discharge and Monitoring Point 9: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	7.8	9.3	9.7	NA
Nitrogen oxides	parts per million	Continuous	2.8	7.5	10.3	25
Oxygen (O ₂)	Percent	Continuous	12.2	12.5	13.8	NA
Temperature	Degrees Celsius	Continuous	76.0	85.8	94.4	NA
Volumetric flow rate	cubic metres per second	Continuous	236.9	368.8	412.5	NA

Discharge and Monitoring Point 13: Air emissions monitoring

Pollutant	Unit of Measure	No. of Samples required	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Moisture content	Percent	Continuous	10.0	10.0	10.0	NA
Nitrogen oxides	parts per million	Continuous	10.4	13.3	17.4	25
Oxygen (O ₂)	Percent	Continuous	13.0	13.2	13.6	NA
Temperature	Degrees Celsius	Continuous	624.7	640.8	657.4	NA
Velocity	Meters per second	Continuous	37.5	51.9	59.7	NA
Volumetric flow rate	cubic metres per second	Continuous	330.5	465.2	536.9	NA

Notes: Moisture content substituted for conservative value of 10%

14 October 2025

B3 Volume or Mass Monitoring Summary***Monitoring Point 3: Sewage volume monitoring***

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	11	69	100

Notes: ** Continuous data recorded via inline flow meter

Comments: