

EnergyAustralia Yallourn Pty Ltd

Monthly Air Emissions Compliance Report

February 2026



EnergyAustralia
LIGHT THE WAY

Monthly Discharge to Air Compliance Executive Summary

Monthly Discharge to Air Compliance Executive Summary				
Indicator	Carbon Monoxide	Oxides of Nitrogen (as NO ₂)	Particles (Total)	Sulphur Dioxide
Maximum Licence Limit (g/min)	139,000	51,600	24,100	104,000
Monthly Maximum Reported (g/min)	39,711	24,981	12,163	46,573
90th Percentile Licence Limit (g/min)	85,600	49,100	14,500	73,100
YTD Month End 90th Percentile (g/min)	16,723	22,273	10,218	40,845
Discharge to Air Licence Limit Compliance	100%	100%	100%	100%
Monitoring System Availability (%)	100%	100%	100%	100%

EPA Operating Licence Site Details

Licence Holder	EnergyAustralia Yallourn PTY LTD
Licence Number	OL000010961
Premises Address	Eastern Rd, Yallourn VIC 3825
Site Description	This licence applies to a premises, where brown coal is mined and electricity is generated in a brown coal fired power station.
Reporting Period	February 2026
Licence Discharge Points	A1: Latitude -38.1769981; Longitude 146.345441
	A2a: Latitude -38.1769981; Longitude 146.3454416
	A2b: Latitude -38.1772303; Longitude 146.3447922
Websites	Permission Information and Performance Statements
	Types of Operating Licences
	EPA AirWatch
	Latrobe Valley Air Monitoring Network Inc.

Discharge to Air Licence Limits

Discharge Point		Indicator	Units [1]	90th Percentile Limit [2]	Maximum Limit	Frequency[3]
A1, A2a, A2b	Bubble Limit for A1, A2a, A2b	Carbon Monoxide	g/min	85,600	139,000	Continuous
		Oxides of Nitrogen (as NO ₂)	g/min	49,100	51,600	Continuous
		Particles (Total)	g/min	14,500	24,100	Continuous
		Sulfur Dioxide	g/min	73,100	104,000	Continuous

[1] g/min =grams per minute 30-minute average

[2] 90th percentile limits are based on a 12-month rolling average

Monthly Air Emissions Daily Performance

Indicator	Carbon Monoxide Daily Maximum (g/min)	Oxides of Nitrogen (as NO ₂) Daily Maximum (g/min)	Particles (Total) ^[5] Daily Maximum (g/min)	Sulfur Dioxide Daily Maximum (g/min)
Maximum Limits	139,000	51,600	24,100	104,000
01-Feb-26	8,683	14,009	7,119	12,611
02-Feb-26	13,440	14,173	6,400	12,403
03-Feb-26	11,311	19,221	7,209	15,143
04-Feb-26	17,872	21,202	6,487	15,498
05-Feb-26	14,419	13,314	5,154	14,328
06-Feb-26	12,321	18,390	5,637	14,612
07-Feb-26	11,945	16,146	6,319	34,675
08-Feb-26	10,333	17,016	7,383	46,419
09-Feb-26	16,686	14,398	6,943	46,573
10-Feb-26	11,649	16,966	7,224	34,620
11-Feb-26	12,125	24,723	6,765	23,136
12-Feb-26	9,620	13,802	6,124	19,823
13-Feb-26	17,434	13,715	6,267	33,388
14-Feb-26	13,315	15,419	8,142	34,347
15-Feb-26	10,354	16,428	6,381	29,128
16-Feb-26	39,711	21,310	9,819	28,088
17-Feb-26	26,981	24,981	7,513	24,175
18-Feb-26	32,164	18,167	11,751	22,388
19-Feb-26	19,799	17,539	10,692	34,085
20-Feb-26	17,131	24,155	9,470	26,745
21-Feb-26	15,734	21,640	8,778	22,165
22-Feb-26	20,350	19,402	10,459	27,697
23-Feb-26	19,298	17,639	9,219	23,231
24-Feb-26	28,260	22,836	9,711	21,409
25-Feb-26	12,999	17,895	9,990	36,037
26-Feb-26	20,175	18,093	10,581	31,403
27-Feb-26	35,250	18,656	12,163	33,194
28-Feb-26	23,538	17,836	10,195	34,454

Air Emissions 90th Percentile Performance [2]

Air Emissions 90th Percentile Performance [2]				
	Carbon Monoxide (g/min)	Oxides of Nitrogen (as NO ₂) (g/min)	Particles (Total) [4] (g/min)	Sulfur Dioxide (g/min)
90th Percentile Licence Limits	85,600	49,100	14,500	73,100
90th Percentile (Month End)	16,723	22,273	10,218	40,845

[2] 90th percentile limits are based on a 12-month rolling average

[4] In accordance with licence condition LI_DA1.10.3 & and LI_DA1.10.4 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

Monthly Data Explanation

Licence Limit Exceedances

This table provides a summary and explanation of exceedances of air discharge limits

Date	Indicator Exceeded	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	No exceedances of licence conditions were reported for the month.

Monthly Data Explanation

Monitoring Systems Availability

This table provides a summary of missing data periods requiring substitutions used for determination of daily co

Date/Time	Loss of Availability (% of month)	Indicator	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	N/A	No Data losses were reported for the month.

Monthly Data Explanation

Amendments to previous Monthly Reports

No Amendments Required

Yallourn Power Station - Licenced Discharge to Air Points

