

# EnergyAustralia Yallourn Pty Ltd

## Monthly Air Emissions Compliance Report

April 2026



**EnergyAustralia**  
LIGHT THE WAY

# Monthly Discharge to Air Compliance Executive Summary

Monthly Discharge to Air Compliance Executive Summary				
Indicator	Carbon Monoxide	Oxides of Nitrogen (as NO <sub>2</sub> )	Particles (Total)	Sulphur Dioxide
<b>Maximum Licence Limit (g/min)</b>	<b>139,000</b>	<b>51,600</b>	<b>24,100</b>	<b>104,000</b>
Monthly Maximum Reported (g/min)	33,665	25,689	14,908	63,025
<b>90th Percentile Licence Limit (g/min)</b>	<b>85,600</b>	<b>49,100</b>	<b>14,500</b>	<b>73,100</b>
YTD Month End 90th Percentile (g/min)	16,191	21,712	9,855	40,488
<b>Discharge to Air Licence Limit Compliance</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>	<b>100%</b>
Monitoring System Availability (%)	100%	100%	100%	100%

# EPA Operating Licence Site Details

<b>Licence Holder</b>	EnergyAustralia Yallourn PTY LTD
<b>Licence Number</b>	OL000010961
<b>Premises Address</b>	Eastern Rd, Yallourn VIC 3825
<b>Site Description</b>	This licence applies to a premises, where brown coal is mined and electricity is generated in a brown coal fired power station.
<b>Reporting Period</b>	April 2026
<b>Licence Discharge Points</b>	A1: Latitude -38.1769981; Longitude 146.345441
	A2a: Latitude -38.1769981; Longitude 146.3454416
	A2b: Latitude -38.1772303; Longitude 146.3447922
<b>Websites</b>	<a href="#">Permission Information and Performance Statements</a>
	<a href="#">Types of Operating Licences</a>
	<a href="#">EPA AirWatch</a>
	<a href="#">Latrobe Valley Air Monitoring Network Inc.</a>

# Discharge to Air Licence Limits

Discharge Point		Indicator	Units [1]	90th Percentile Limit [2]	Maximum Limit	Frequency[3]
A1, A2a, A2b	Bubble Limit for A1, A2a, A2b	Carbon Monoxide	g/min	85,600	139,000	Continuous
		Oxides of Nitrogen (as NO <sub>2</sub> )	g/min	49,100	51,600	Continuous
		Particles (Total)	g/min	14,500	24,100	Continuous
		Sulfur Dioxide	g/min	73,100	104,000	Continuous

[1] g/min =grams per minute 30-minute average

[2] 90th percentile limits are based on a 12-month rolling average

# Monthly Air Emissions Daily Performance

## Monthly Air Emissions Daily Performance

Indicator	Carbon Monoxide Daily Maximum (g/min)	Oxides of Nitrogen (as NO <sub>2</sub> ) Daily Maximum (g/min)	Particles (Total) Daily Maximum (g/min)	Sulfur Dioxide Daily Maximum (g/min)
<b>Maximum Limits</b>	<b>139,000</b>	<b>51,600</b>	<b>24,100</b>	<b>104,000</b>
01-Apr-26	19,212	22,516	8,546	42,700
02-Apr-26	15,049	18,251	7,727	37,697
03-Apr-26	13,132	18,439	10,478	27,197
04-Apr-26	8,512	18,259	6,727	24,952
05-Apr-26	23,721	18,763	7,703	24,935
06-Apr-26	29,826	23,414	13,271	37,325
07-Apr-26	17,830	22,402	12,951	38,889
08-Apr-26	14,947	25,689	13,367	39,467
09-Apr-26	18,344	24,714	11,452	33,773
10-Apr-26	7,768	16,845	6,879	28,093
11-Apr-26	5,519	16,884	7,019	22,747
12-Apr-26	11,307	17,093	8,124	26,848
13-Apr-26	19,913	19,907	9,080	31,250
14-Apr-26	18,088	18,762	9,062	29,675
15-Apr-26	13,822	19,145	8,120	30,358
16-Apr-26	15,422	18,661	8,386	30,981
17-Apr-26	16,048	17,228	11,318	29,598
18-Apr-26	33,524	17,829	8,087	42,846
19-Apr-26	9,108	19,785	11,781	58,393
20-Apr-26	9,164	19,021	12,567	59,770
21-Apr-26	15,367	19,252	9,417	30,276
22-Apr-26	26,515	19,011	8,313	29,186
23-Apr-26	15,922	17,443	8,233	55,449
24-Apr-26	15,403	18,780	9,406	59,116
25-Apr-26	11,127	19,244	9,444	34,575
26-Apr-26	11,571	20,078	8,566	29,431
27-Apr-26	14,572	20,474	8,502	30,136
28-Apr-26	11,400	20,942	10,645	29,963
29-Apr-26	16,307	18,707	14,908	35,620
30-Apr-26	33,665	17,707	8,505	63,025

[3] In accordance with licence condition LI\_DA1.10.3 & and LI\_DA1.10.4 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

# Air Emissions 90th Percentile Performance [2]

Air Emissions 90th Percentile Performance [2]				
	Carbon Monoxide (g/min)	Oxides of Nitrogen (as NO <sub>2</sub> ) (g/min)	Particles (Total) [4] (g/min)	Sulfur Dioxide (g/min)
90th Percentile Licence Limits	85,600	49,100	14,500	73,100
90th Percentile (Month End)	16,191	21,712	9,855	40,488

[2] 90th percentile limits are based on a 12-month rolling average

[4] In accordance with licence condition LI\_DA1.10.3 & and LI\_DA1.10.4 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

# Monthly Data Explanation

## Licence Limit Exceedances

This table provides a summary and explanation of exceedances of air discharge limits

Date	Indicator Exceeded	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	No exceedances of licence conditions were reported for the month.

# Monthly Data Explanation

## Monitoring Systems Availability

This table provides a summary of missing data periods requiring substitutions used for determination of daily co

Date/Time	Loss of Availability (% of month)	Indicator	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	N/A	No Data losses were reported for the month.

# Monthly Data Explanation

## Amendments to previous Monthly Reports

No Amendments Required

# Yallourn Power Station - Licenced Discharge to Air Points

