

EnergyAustralia Yallourn Pty Ltd

Monthly Air Emissions Compliance Report

June 2026



EnergyAustralia
LIGHT THE WAY

Monthly Discharge to Air Compliance Executive Summary

Monthly Discharge to Air Compliance Executive Summary				
Indicator	Carbon Monoxide	Oxides of Nitrogen (as NO ₂)	Particles (Total)	Sulphur Dioxide
Maximum Licence Limit (g/min)	139,000	51,600	24,100	104,000
Monthly Maximum Reported (g/min)	40,256	30,026	15,884	63,749
90th Percentile Licence Limit (g/min)	85,600	49,100	14,500	73,100
YTD Month End 90th Percentile (g/min)	16,145	24,325	10,149	43,758
Discharge to Air Licence Limit Compliance	100%	100%	100%	100%
Monitoring System Availability (%)	100%	100%	100%	100%

EPA Operating Licence Site Details

Licence Holder	EnergyAustralia Yallourn PTY LTD
Licence Number	OL000010961
Premises Address	Eastern Rd, Yallourn VIC 3825
Site Description	This licence applies to a premises, where brown coal is mined and electricity is generated in a brown coal fired power station.
Reporting Period	June 2026
Licence Discharge Points	A1: Latitude -38.1769981; Longitude 146.345441
	A2a: Latitude -38.1769981; Longitude 146.3454416
	A2b: Latitude -38.1772303; Longitude 146.3447922
Websites	Permission Information and Performance Statements
	Types of Operating Licences
	EPA AirWatch
	Latrobe Valley Air Monitoring Network Inc.

Discharge to Air Licence Limits

Discharge Point		Indicator	Units [1]	90th Percentile Limit [2]	Maximum Limit	Frequency
A1, A2a, A2b	Bubble Limit for A1, A2a, A2b	Carbon Monoxide	g/min	85,600	139,000	Continuous
		Oxides of Nitrogen (as NO ₂)	g/min	49,100	51,600	Continuous
		Particles (Total)	g/min	14,500	24,100	Continuous
		Sulfur Dioxide	g/min	73,100	104,000	Continuous

[1] g/min =grams per minute 30-minute average

[2] 90th percentile limits are based on a 12-month rolling average

Monthly Air Emissions Daily Performance

Monthly Air Emissions Daily Performance				
Indicator	Carbon Monoxide Daily Maximum (g/min)	Oxides of Nitrogen (as NO ₂) Daily Maximum (g/min)	Particles (Total)[5] Daily Maximum (g/min)	Sulfur Dioxide Daily Maximum (g/min)
Maximum Limits	139,000	51,600	24,100	104,000
01-Jun-26	9,518	29,017	13,669	46,990
02-Jun-26	40,256	29,336	13,009	40,526
03-Jun-26	17,758	20,290	6,933	40,460
04-Jun-26	18,114	23,895	12,052	48,329
05-Jun-26	33,984	27,808	11,476	63,749
06-Jun-26	16,862	29,106	11,445	61,585
07-Jun-26	22,914	30,026	11,036	54,391
08-Jun-26	13,644	29,026	10,927	51,166
09-Jun-26	7,765	27,806	8,795	36,469
10-Jun-26	21,637	27,812	10,049	42,271
11-Jun-26	14,299	26,601	13,418	39,374
12-Jun-26	6,155	25,065	11,251	33,070
13-Jun-26	27,591	25,645	10,510	35,203
14-Jun-26	13,249	26,499	9,859	37,655
15-Jun-26	14,534	26,083	10,366	36,154
16-Jun-26	19,458	25,284	9,192	41,264
17-Jun-26	8,111	22,715	9,746	52,157
18-Jun-26	11,722	20,055	11,183	51,137
19-Jun-26	7,098	19,032	7,504	50,195
20-Jun-26	4,825	18,058	7,364	45,709
21-Jun-26	5,516	19,400	7,389	38,393
22-Jun-26	5,199	18,964	7,225	34,191
23-Jun-26	5,976	20,829	7,813	31,566
24-Jun-26	8,092	27,478	11,094	33,790
25-Jun-26	12,521	23,641	11,017	31,869
26-Jun-26	26,290	27,188	10,194	36,951
27-Jun-26	19,206	28,302	10,514	36,372
28-Jun-26	19,447	26,919	14,690	37,088
29-Jun-26	35,092	26,426	12,920	37,439
30-Jun-26	30,967	26,026	15,884	37,786

[3] In accordance with licence condition LI_DA1.10.3 & and LI_DA1.10.4 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

Air Emissions 90th Percentile Performance [2]

Air Emissions 90th Percentile Performance [2]				
	Carbon Monoxide (g/min)	Oxides of Nitrogen (as NO ₂) (g/min)	Particles (Total) [4] (g/min)	Sulfur Dioxide (g/min)
90th Percentile Licence Limits	85,600	49,100	14,500	73,100
90th Percentile (Month End)	16,145	24,325	10,149	43,758

[2] 90th percentile limits are based on a 12-month rolling average

[4] In accordance with licence condition LI_DA1.10.3 & and LI_DA1.10.4 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

Monthly Data Explanation

Licence Limit Exceedances

This table provides a summary and explanation of exceedances of air discharge limits

Date	Indicator Exceeded	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	No exceedances of licence conditions were reported for the month.

Monthly Data Explanation

Monitoring Systems Availability

This table provides a summary of missing data periods requiring substitutions used for determination of daily co

Date/Time	Loss of Availability (% of month)	Indicator	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	N/A	No Data losses were reported for the month.

Monthly Data Explanation

Amendments to previous Monthly Reports

No Amendments Required

Yallourn Power Station - Licenced Discharge to Air Points

