

EnergyAustralia Yallourn Pty Ltd

Monthly Air Emissions Compliance Report

July 2026



EnergyAustralia
LIGHT THE WAY

Monthly Discharge to Air Compliance Executive Summary

Monthly Discharge to Air Compliance Executive Summary				
Indicator	Carbon Monoxide	Oxides of Nitrogen (as NO ₂)	Particles (Total)	Sulphur Dioxide
Maximum Licence Limit (g/min)	139,000	51,600	24,100	104,000
Monthly Maximum Reported (g/min)	70,420	29,456	16,409	67,548
90th Percentile Licence Limit (g/min)	85,600	49,100	14,500	73,100
YTD Month End 90th Percentile (g/min)	15,778	24,815	10,157	44,077
Discharge to Air Licence Limit Compliance	100%	100%	100%	100%
Monitoring System Availability (%)	100%	100%	100%	100%

EPA Operating Licence Site Details

Licence Holder	EnergyAustralia Yallourn PTY LTD
Licence Number	OL000010961
Premises Address	Eastern Rd, Yallourn VIC 3825
Site Description	This licence applies to a premises, where brown coal is mined and electricity is generated in a brown coal fired power station.
Reporting Period	July 2026
Licence Discharge Points	A1: Latitude -38.1769981; Longitude 146.345441
	A2a: Latitude -38.1769981; Longitude 146.3454416
	A2b: Latitude -38.1772303; Longitude 146.3447922
Websites	Permission Information and Performance Statements
	Types of Operating Licences
	EPA AirWatch
	Latrobe Valley Air Monitoring Network Inc.

Discharge to Air Licence Limits

Discharge Point		Indicator	Units [1]	90th Percentile Limit [2]	Maximum Limit	Frequency
A1, A2a, A2b	Bubble Limit for A1, A2a, A2b	Carbon Monoxide	g/min	85,600	139,000	Continuous
		Oxides of Nitrogen (as NO ₂)	g/min	49,100	51,600	Continuous
		Particles (Total)	g/min	14,500	24,100	Continuous
		Sulfur Dioxide	g/min	73,100	104,000	Continuous

[1] g/min =grams per minute 30-minute average

[2] 90th percentile limits are based on a 12-month rolling average

Monthly Air Emissions Daily Performance

Monthly Air Emissions Daily Performance				
Indicator	Carbon Monoxide Daily Maximum (g/min)	Oxides of Nitrogen (as NO ₂) Daily Maximum (g/min)	Particles (Total)[3] Daily Maximum (g/min)	Sulfur Dioxide Daily Maximum (g/min)
Maximum Limits	139,000	51,600	24,100	104,000
01-Jul-26	25,285	19,791	16,409	31,944
02-Jul-26	11,309	19,302	10,642	61,077
03-Jul-26	12,383	24,624	13,013	52,178
04-Jul-26	10,990	26,096	12,460	60,216
05-Jul-26	11,504	27,018	11,704	62,040
06-Jul-26	12,722	28,754	12,471	67,548
07-Jul-26	24,743	27,664	12,258	52,120
08-Jul-26	24,695	29,291	12,386	47,737
09-Jul-26	13,534	28,744	12,183	43,329
10-Jul-26	18,661	29,456	9,959	56,354
11-Jul-26	7,816	26,197	9,334	53,024
12-Jul-26	7,450	25,700	9,551	54,268
13-Jul-26	11,277	25,661	8,587	48,904
14-Jul-26	70,420	27,001	10,823	43,421
15-Jul-26	22,309	27,012	11,884	47,550
16-Jul-26	23,114	25,615	11,782	50,750
17-Jul-26	24,238	24,960	10,825	47,985
18-Jul-26	12,158	25,406	10,439	44,764
19-Jul-26	25,727	25,565	10,152	48,763
20-Jul-26	16,642	25,445	10,262	43,642
21-Jul-26	20,481	25,811	9,973	40,172
22-Jul-26	34,106	25,713	11,143	43,832
23-Jul-26	17,675	24,737	9,995	42,789
24-Jul-26	21,710	25,304	10,398	43,775
25-Jul-26	41,058	26,125	10,706	42,309
26-Jul-26	21,951	26,136	10,845	42,040
27-Jul-26	18,712	26,567	11,433	58,988
28-Jul-26	20,702	25,437	10,858	58,638
29-Jul-26	15,853	25,482	12,340	45,274
30-Jul-26	16,901	26,125	11,935	44,600
31-Jul-26	17,043	24,804	13,514	41,454

[3] In accordance with licence condition OL_DA01.10.03 & OL_DA01.10.04 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

Air Emissions 90th Percentile Performance [2]

Air Emissions 90th Percentile Performance [2]				
	Carbon Monoxide (g/min)	Oxides of Nitrogen (as NO ₂) (g/min)	Particles (Total) [3] (g/min)	Sulfur Dioxide (g/min)
90th Percentile Licence Limits	85,600	49,100	14,500	73,100
90th Percentile (Month End)	15,778	24,815	10,157	44,077

[2] 90th percentile limits are based on a 12-month rolling average

[3] In accordance with licence condition OL_DA01.10.03 & OL_DA01.10.04 the discharge limits for particles do not apply during the plant start-up and shut-down or the accidental failure of major operating equipment and has been excluded from this daily total.

Monthly Data Explanation

Licence Limit Exceedances

This table provides a summary and explanation of exceedances of air discharge limits

Date	Indicator Exceeded	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	No exceedances of licence conditions were reported for the month.

Monthly Data Explanation

Monitoring Systems Availability

This table provides a summary of missing data periods requiring substitutions used for determination of daily co

Date/Time	Loss of Availability (% of month)	Indicator	Location (A1, A2a, A2b)	Explanation
N/A	N/A	N/A	N/A	No Data losses were reported for the month.

Monthly Data Explanation

Amendments to previous Monthly Reports

No Amendments Required

Yallourn Power Station - Licenced Discharge to Air Points

