### **Monitoring and Complaints Summary** В

Period: 1/06/2021 to 1/07/2021

0

0

#### **Number of Pollution Complaints** B1

aints 0		
Number of Complaints		
0	EPL Number:	555
0	Licensee's name: EN	JERGYAUSTRALIA T
0	Licensee's address: Ta	llawarra Power Sta
	1	

13 July 2021 TALLAWARRA ation, Princes Highway, YALLAH, NSW 2530 Link to EPL: http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=555&id=555&opt ion=licence&searchrange=licence&range=POEO%20licence&prp=no&status=L ssued

#### B2 **Concentration Monitoring Summary**

**Pollution Category** 

Air

Water

Noise

Waste

Other

Monitoring Point 2: Effluent quality monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	28/06/2021	5	5	5	20
Total suspended solids	milligrams per litre	Special Frequency 1	1	28/06/2021	25	25	25	30

Comments:



	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit	
	Continuous	NA	12.2	13.5	15.7	NA*	<b>Energy</b> Australia
w	ater quality licence	limits for ambien	t water quali	ty monitoring	g in its EPL. AN	NZECC Guide	lines apply to

13 July 2021



Unit of

No. of

Samples

Pollutant	Measure	required	collected	collected	value	sample	value	Limit	<b>F</b>
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.2	13.5	15.7	NA*	En
Notes:	*Tallawarra do	es not have w	ater quality licence l	imits for ambien	t water quali	ty monitoring	r in its FPI ΔI	VZECC Guide	lines ann

\*Tallawarra does not have water qu Notes: iiity quality пg appiy receiving waters

Periods where the plant is offline or Thermoshock is active have been removed from this data set. Comments:

## Discharge and Monitoring Point 5: Discharge water quality monitoring

Pollutant	Unit of Measure		No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	12.4	16.2	20.2	35

Periods where the plant is offline have been removed from this data set. Comments:

Monitoring Point 6: Ambient water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Temperature	Degrees Celsius	Continuous	Continuous	NA	11.3	13.6	16.6	NA*

Comments: n/a

Monitoring Point 7: Ambient water monitoring

		No. of			Lowest		Highest	
	Unit of	Samples	No. of samples	Date samples	sample	Mean of	sample	Licence
Pollutant	Measure	required	collected	collected	value	sample	value	Limit
	Degrees	Continuous	Continuous	NIA	11.0	12.0	15.0	NI A *
Temperature	Celsius	Continuous	Continuous	NA	11.8	13.6	15.6	NA*

Comments: n/a



13 July 2021

Monitoring Point 8: Discharge water monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date samples collected	Lowest sample value	Mean of sample	Highest sample value	Licence Limit
Copper	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*
Nitrogen (total)	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
рН	рН	Monthly during discharge	0	-	-	-	-	NA*
Total Phosporous - filtered sample	milligrams per litre	discharge	0	-	-	-	-	NA*
Total suspended solids	milligrams per litre	Monthly during discharge	0	-	-	-	-	NA*
Zinc	micrograms per litre	Monthly during discharge	0	-	-	-	-	NA*



13 July 2021

Notes: \*Tallawarra does not have water quality licence limits for ambient water quality monitoring in its EPL. ANZECC. Guidelines apply to receiving waters

Comments: No discharge this month.

Highest

Discharge and Monito	oring Point 9: Air	emissions monito	ring	
	No. of			Lowest
Unit of	Samples	No. of samples	Date samples	sample



Pollutant	Unit of Measure	Samples required	No. of samples collected	Date samples collected	sample value	Mean of sample	sample value	Licence Limit
Carbon dioxide	%	Continuous	**	NA	3.6	4.1	4.5	NA
Moisture content	Percent	Continuous	**	NA	7.3	8.1	9.1	NA
Nitrogen oxides	parts per million	Continuous	**	NA	3.6	8.2	15.9	25
Oxygen (O2)	Percent	Continuous	**	NA	12.9	13.5	14.1	NA
Solid particles	milligrams per cubic metre	Yearly	1	24/07/2020	-	<0.4	-	10
Sulphur dioxide	parts per million	Yearly	1	24/07/2020	-	<2	-	3
Temperature	Degrees Celsius	Continuous	**	NA	69.4	79.8	105.4	NA
Volatile organic compounds	parts per million	Yearly	1	24/07/2020	-	<100	-	NA
Volumetric flow rate	cubic metres per second	Continuous	**	NA	244.1	332.0	438.1	NA

\* equipment detection limit Notes:

Comments:

# B3 Volume or Mass Monitoring Summary

Monitoring Point 3: Sewage volume monitoring

Pollutant	Unit of Measure	No. of Samples required	No. of samples collected	Date Samples collected	Lowest result	Mean result	Highest result	Licence Limit
Sewage	Kilolitres per day	Continuous	**	NA	0	5	22	100

Notes: \*\* Continuous data recorded via inline flow meter

Comments:



13 July 2021